

Electric System Fragility SERA - ShakeMap

February 4 2022

John Eidinger

©G&E Engineering Systems Inc. 2022

Notice: this presentation is not endorsed by the US Federal Government, the USGS, any Utility or any Manufacturer.
No warranty or guaranty of any sort is made by G&E or the author. This information may not be applicable to your situation.
You are free to use this material if you agree with the terms and conditions on the G&E web site, NOTICES, <http://www.geEngineeringSystems.com>
Anyone who uses this material for any purpose does so at their own sole risk and you indemnify G&E and the authors entirely. If you do not agree, do not use this material.



Agenda

- Engineers who ask Lots of Questions
- Anchorage 2018 Electric System Damage
- Empirical Data - 72 earthquakes
- Test Data - Modern
- Distribution Systems - the \$300 Billion Elephant in the room no one talks about
- Questions and Comments



Key Points

- Substations: We have "nearly solved" the seismic vulnerability. Some utilities are well on their way to implementation. Some utilities are like Dinosaurs.
- Distribution Systems: The Elephant on the room
- How much to complete the job? Brute force = \$300,000,000,000 for California.
- SERA and ShakeMaps: tools to quantify, evaluate, and make smart decisions. Maybe find a \$40 B mitigation plan that does 95% of the \$300 B brute force plan.





Anshel Schiff

Alex Tang




Communication
Battery



Anshel Schiff in Oregon

Pot Heads



Anshel Schiff in Canada

John MacKenzie, Transpower + Orion's seismic designer engineer



John and John in New Zealand





Will Liquefaction Damage a 230 kV Rigid Bus Substation at $PGA = 0.5g$?

Large sand boil in 220 kV Yard





What about the millions of small stuff?



When we see this..... With a little coordination,
2 months later we are going to test!







MEA Briggs Substation





Rigid Bus. Surge Arrestors. Transformer slid, breaking 2 bushings.+ 2 SAs.
PGA ~ 0.30g



MEA Douglas Substation


Rigid Bus Expansion Joints, Bus Supports. PGA ~ 0.30g



Excessive differential movements leads to failures
Switch steel structures and bus supports
use I-beams, low frequencies,
twisting / torsion. All this is readily computed.
Suitable connectors are available.
Do utilities (and their A/Es) turn a blind eye?
Sunshine will expose the weaknesses.
CEA, ML&P and MEA all have work to do.




MEA Anderson Substation



Surge Arrestors. Circuit Switchers (candlestick breakers)
PGA ~ 0.30g




MEA Pippel Substation



Candlestick Breaker. Surge Arrestors. Bus. 115 kV DS + CB. PGA ~ 0.30g




 Damaged

 Undamaged

CEA
Pt MacKenzie 2018
230 138 kV
Lat 61.2496
Long -150.0268

North




230 kV Yard

Yard Status December 4 2018




Imagery Date: 4/14/2011 lat 61.249038°





Damaged



Key Findings

- Modern Seismic-Qualified Substations: a **WHOLE LOT BETTER** than what was originally built in the 1960s and 1970s
- Old, vulnerable equipment had Fragility levels $PGA = 0.2g$ to $0.5g$
- New, qualified equipment has Fragility levels commonly $PGA = 1.3g+$



Why do we still have power outages?

- There remain (relatively minor) weaknesses at substations (mostly related to the bus)
- HUGE: the low voltage distribution system
 - Buried Cables: ~450 failures in 2010/2011
 - Overhead: ~1,000 failures in M 7; 50 failures in M 6.
 - What will a M 8 (San Andreas) produce: 5,000 failures? Or a Compton M 7 thrust event?



Consider the Issues

- Low Voltage: commonly 16-32 manhours per repair
- 50 repairs * 16 manhours = 800 manhours.
 - Apply 50 repair people @ 12 hours / day, you are done in 32 hours. People are “happy”
- 5,000 repairs * 20 manhours = 100,000 manhours.
 - Apply 1,000 repair people @ 12 hours / day, you are done in 8.33 days (200 hours). People are “not happy”



What should Utilities do?

- Continue procurement of IEEE 693 qualified equipment. ✓ ✓ ✓ ✓ ✓ ✓
- Implement better cable flex bus and rigid bus detailing. ✓ ✓ ✓ ✓ ✓ ✓
- Bury low voltage feeders (\$300 Billion for California). CEO Patricia Pope recently announced the first \$20 Billion for PG&E. 90% improvement
- Emergency plans to use 10,000 repair people. COST EFFECTIVE
- Seismic design for low voltage overheads (insulated cables, no drop spans, torsion design for elevated multi-transformers, deeper embedment in liquefaction zones). CPUC / Boards to allow this to be recovered in rates.
- “Smart” de-energization? Can reduce about 20% of overhead repairs. Unthinkable 30 years ago. Technically feasible today. Can a Utility depend on third parties? A \$10,000,000 grant from Congress's latest \$1.1 T Infrastructure plan might kick start a demonstration project - Who will step up to the plate? An investor-owned utility? A public-owned utility?



Where to get Reports

- <http://www.geEngineeringSystems.com>
- All free - see copyright, creative commons deed on the web site
- Books (typ. 300 pages) that describe seismic fragility models for:
 - Natural Gas Pipes
 - Water Pipes (Tanks, Levees, Tunnels)
 - Electric Utility Components (new multi-volume report late 2022)
 - Non Structural Components
 - Fire Following Earthquake
- New TCLEE Reports No. 1 through 7 (earthquakes 2014 through 2021)



What is SERA?

- **S**ystem **E**arthquake **R**isk **A**nalysis
- 32 years of development
- Available by license to Utilities



SERA and ShakeMap

- **SERA** allows several kinds of earthquakes: User-defined Scenario, USGS Probabilistic, ShakeMap, User-defined Probabilistic
- After most earthquakes $M > 5$, run SERA within a few minutes post-earthquake. If SERA predicts power outages or damage, engineers will go out to inspect and verify.
- Current Interface: ShakeMap grid.xyz or grid.xml file.
- Better interface: Stationlist.txt (the raw data)



Good, Bad, (and the Ugly)

- **GOOD.** grid.xyz files are “free”. Gives a quick look at what the range of damage / power outages might be.
- **BAD.** grid.xyz Initial release files (< 1 hour) are unreliable. Beta is not $0.5 \pm$. It can be $\gg 0.5$. Revised files might take 5+ years to create. Improper data may exist for a long time (eg. Carquinez instruments that measured bridge pounding with PGA ~ 1.0g are still embedded in the Napa 2014 ShakeMaps)
- **Fine points.** Mish mash of DYFI and instrumental values gives artificial smoothing. MMI is NOT the way to go if you want better loss estimates.
- A “**smarter**” Shakemap would use the instrumental data (from USGS) and utility-specific Vs30, GMPE, basin, liquefaction, landslide, surface faulting info.
- “**Standardized**” Shakemap files. Drudgery of writing / updating parsers and exception handling for shifting .xyz, .xml, .json, .txt, .shp file formats. PLEASE Include "legacy" file formats even if new ones are added.



ShakeMap SERA Merge?

- SERA 2030 vision: maintenance by the utilities.
- David Wald and crew are plenty darn smart.
- Can the US Federal Government maintain the electric grid infrastructure?



SERA MODELS - LARGE ELECTRIC

BC Hydro. 483 substations

BPA. 521 substations

PG&E. 981 substations

SCE. 1247 substations

SDG&E. 58 substations

PacifiCorp. 1400 substations

Total.

About 5,000 substations

350,000 transmission towers

11 million wood poles

60 million people




Epicenters of
Historical Earthquakes

PG&E Service Area

72 Earthquakes
1980 - 2020, $M \geq 4.5$

plus...

\$20 Billion after M 6.0 2021




EQ	Name	M	Event Date	Max PGA, g	EventID
72	White Wolf	7.2	07/21/1952	0.5068	Whitewolf
29	Greenville	5.8	01/24/1980	0.2275	19800124190009
30	Greenville	5.4	01/27/1980	0.2625	19800127023336
10	Central CA	6.1	05/25/1980	0.3050	19800525163347
33	Humboldt Offshore	7.2	11/08/1980	1.5237	19801108000000
61	Coalinga	6.3	05/02/1983	0.7161	19830502234237
39	Morgan Hill	6.2	04/24/1984	0.6277	19840424211520
62	Ridgemark	5.4	01/26/1986	0.1367	19860126192051
63	Calaveras	5.6	03/31/1986	0.2050	19860331115540
35	Loma Prieta	6.9	10/19/1989	0.7876	19891019000000
31	Honeydew	6.1	08/17/1991	0.5780	19910817192940
43	Cape Mendocino	7.2	04/25/1992	1.1658	269151
6	California City	5.3	07/11/1992	0.0967	19920711181416
24	Gilroy	4.9	01/16/1993	0.0959	19930116062934
21	Gardnerville	5.7	09/12/1994	0.2976	19940912122343
32	Humboldt	5.5	12/26/1994	0.1997	19941226141029
51	Smith Valley	5.5	12/28/1995	0.1617	19951228182759
48	Salinas	5.2	08/12/1998	0.2451	19980812141026
36	Mammoth Lakes	5.5	05/15/1999	0.1390	19990515132210
5	Bolinas	4.6	08/17/1999	0.1696	21044694
12	Cloverdale	4.6	01/11/2000	0.0261	21076750
60	Yountville	5.0	09/03/2000	0.3664	20000903083630
3	Blairden	5.2	08/10/2001	0.3149	21188442
46	Pinnacles	4.6	12/28/2001	0.0256	21207275
20	Ferndale	4.6	04/28/2002	0.0183	21223451
26	Gilroy	4.9	05/13/2002	0.4831	21254601
2	Bayview	5.2	06/17/2002	0.0652	21231051
50	San Simeon	6.5	12/22/2003	0.9057	20031222191558
7	Cambria	4.7	12/23/2003	0.0598	21324051
13	Cobb	4.6	02/18/2004	0.1814	21344222
11	Cholame	4.7	09/28/2004	0.1411	21400461
4	Bodfish	5.0	09/29/2004	0.1443	14095628
41	Parkfield	5.0	09/29/2004	0.1522	21401069
38	Maricopa	4.6	04/16/2005	0.1520	14138080
53	Tahoe Vista	4.8	06/26/2005	0.2474	21465580

EQ	Name	M	Event Date	Max PGA, g	EventID
28	Grapevine	4.7	09/22/2005	0.1539	14186612
22	Geysers	4.7	05/12/2006	0.0551	21516950
44	Petrolia	5.0	07/19/2006	0.0584	21527987
27	Glen Ellen	4.5	08/02/2006	0.0958	21530368
14	Cobb	4.6	10/20/2006	0.1959	21543835
34	Lake Pillsbury	4.8	04/18/2007	0.0273	40195779
37	Mammoth Lakes	4.6	06/12/2007	0.1901	51182810
15	Alum Rock East Foothills	5.5	10/31/2007	0.1644	40204628
47	Rancho Tehama	4.5	01/19/2008	0.0126	51194914
59	Willow Creek	5.4	04/29/2008	0.0658	40216664
16	East Quincy	4.5	12/16/2008	0.0568	51213957
18	Eureka Offshore	6.5	01/10/2010	0.6031	71338066
49	San Juan Batista	4.5	01/12/2011	0.0663	71508850
45	Pinnacles	4.6	08/27/2011	0.2464	71627835
58	Whitehawk	4.7	10/26/2011	0.1035	71671056
57	Weitchpec	5.6	02/13/2012	0.2343	71734741
54	Talmage	4.5	09/25/2012	0.0169	71847715
40	New Idria	5.3	10/20/2012	0.2514	71863625
8	Susanville Canyon Dam	5.7	05/23/2013	0.8594	71996906
9	Canyon Dam	4.9	05/24/2013	0.3019	71997821
17	Eureka	6.9	03/10/2014	0.3919	72182046
52	South Napa	6.0	08/24/2014	0.6512	72282711
42	Parkfield	4.9	09/30/2014	0.0858	21401170
19	Ferndale	5.7	01/28/2015	0.3811	72387946
56	Wasco	4.9	02/24/2016	0.2184	37528064
1	Bayside	4.7	07/21/2016	0.0798	72664436
23	Geysers	5.0	12/14/2016	0.1124	72737985
55	Upper Lake	5.1	03/17/2017	0.0144	72672610
25	Gilroy	3.3	03/06/2018	0.0099	72979736
70	Petrolia	4.7	03/22/2018	0.1118	72988926
71	Petrolia	5.6	06/22/2019	0.4204	73201181
64	Ridgecrest	6.4	07/04/2019	0.4782	38443183
65	Ridgecrest	7.1	07/06/2019	0.9087	38457511
66	Tres Pinos	4.7	10/15/2019	1.1346	73292360
69	Petrolia	5.2	03/18/2020	0.3413	73355700
68	Johnson Lane	4.5	03/20/2020	0.1500	00719663
67	Bodie	5.2	04/11/2020	0.3355	73367270


Historical Earthquakes: PG&E Service Area: 1952 - 2020




Maximum Horizontal PGA (g)




Magnitude of 72 Events




Count by Magnitude, Number of Events



Maximum PGA, Anywhere in ShakeMap




20 Classes - By Bin, Running Count



Bin size = 0.01g [≤ 0.50 g]; 0.05g [0.55 - 0.80g]; 0.20g [1.0g]
By Record



20 Classes - All Exposures



Bin size = 0.01g [$\leq 0.50g$]; 0.05g [0.55 - 0.80g]; 0.20g [1.0g]
By Record



Records

Show All

New Record

Delete Record

Find

Sort

Share

Layout: Equipment Review

View As

Preview

Edit Layout

Substation Name:

Substation ID:

Component ID:

Latitude_DD:

Longitude_DD:

Voltage:

Tag Number(s):

Manufacturer:

Number Similar:

Fragility ID:

AA CB

SERA_Position:

SERA_T_Line:

Description:

Tie1_ID:

Tie2_ID:

Tie3_ID:

Stack:

Stack2:

POD Stack for Settlement:

Equipment Tag Number:

Cost Assigned:

Site In SERA Model:

Replaced:

Edit Date:

POE_Location:

ISO Criticality:

Manufacturer:

Model Number:

Serial Number:

Part No:

Install Date:

Purchase Date:

Manufactured Date:

Age:

Years:

PSE_Voltage:

Total Weight Lbs:

Phases:

Cost Historic:

Cost 2010:

Interrupt Medium:

Amps:

Oil Main Gate:

Oil Total Gate:

LTC:

Impedance (Pct):

Cooling Type:

Equipment Sub Type:

Primary Voltage kV:

Secondary Voltage kV:

Tertiary Voltage kV:

Max MVA:

Rating 1 MVA:

Rating 2 MVA:

Nameplate MVA:

Temp Rise °C:

Primary Connection:

ByeStatus:

UserStatus:

Year of Manufacture:

TR_ComponentID:

Results (Scenario) Results (ShakeMap)

Event Name	Magnitude	Event Date	In-Use No or 7 Equipment in Service	Median Results			S&S Results			Observed Damage State							
				PGA	Number Damaged	Number Function Failures	ST_Cost	LT_Cost	PGA Damaged		Number Failures	ST_Cost	LT_Cost				
Loma Prieta	6.9	10/17/1989	0	0.209	0.00	0.000	\$0	\$0	0.0	0.00	0.000	\$0	\$0	0.0	Yes	Yes	
Manzan Hill	6.2	4/24/1984	0	0.120	0.00	0.000	\$0	\$0	0.0	0.100	0.00	0.000	\$0	\$0	0.0	Yes	Yes
Greenville	5.8	1/27/1980	0	0.073	0.00	0.000	\$0	\$0	0.0	0.125	0.00	0.000	\$0	\$0	0.0	Yes	Yes
Greenville	5.8	1/24/1980	0	0.073	0.00	0.000	\$0	\$0	0.0	0.123	0.00	0.000	\$0	\$0	0.0	Yes	Yes
Calaveras	5.6	3/31/1986	0	0.062	0.00	0.000	\$0	\$0	0.0	0.109	0.00	0.000	\$0	\$0	0.0	Yes	Yes
East Foothills	5.5	10/31/2007	1	0.047	0.00	0.000	\$0	\$0	0.0	0.083	0.00	0.000	\$0	\$0	0.0	Yes	Yes
Gilroy	4.9	5/13/2002	1	0.016	0.00	0.000	\$0	\$0	0.0	0.030	0.00	0.000	\$0	\$0	0.0	Yes	Yes
Coalinga	6.3	5/3/1965	0	0.012	0.00	0.000	\$0	\$0	0.0	0.019	0.00	0.000	\$0	\$0	0.0	Yes	Yes
South Napa	6.0	8/24/2014	1	0.009	0.00	0.000	\$0	\$0	0.0	0.015	0.00	0.000	\$0	\$0	0.0	Yes	Yes
Hedgemark	5.4	1/26/1986	0	0.006	0.00	0.000	\$0	\$0	0.0	0.011	0.00	0.000	\$0	\$0	0.0	Yes	Yes
Humboldt	5.0	9/3/2000	0	0.005	0.00	0.000	\$0	\$0	0.0	0.010	0.00	0.000	\$0	\$0	0.0	Yes	Yes
Salinas	5.1	6/13/1998	0	0.005	0.00	0.000	\$0	\$0	0.0	0.008	0.00	0.000	\$0	\$0	0.0	Yes	Yes
Gilroy	4.8	1/16/1993	0	0.004	0.00	0.000	\$0	\$0	0.0	0.007	0.00	0.000	\$0	\$0	0.0	Yes	Yes
Salinas	4.6	8/17/1999	0	0.003	0.00	0.000	\$0	\$0	0.0	0.006	0.00	0.000	\$0	\$0	0.0	Yes	Yes
San Juan Batista	4.5	1/2/2011	1	0.002	0.00	0.000	\$0	\$0	0.0	0.003	0.00	0.000	\$0	\$0	0.0	Yes	Yes

Recommendation

Bushing 500 kV:

Bushing 230 kV:

Bushing 115 kV:

Recommendation Date:

Priority Assuming High Hazard:

Seismic Hazard:

UpgradeCostPer Item:

UpgradeCostAllItem:

Fragility Photo



Photo1Path:

Photo2Path:

Photo3Path:

Photo4Path:

Photo5Path:



bushwork failed in 2007 EQ

Original Photo: 1024 w x 681 h Thumbnail Photo: 1024 w x 768 h

NFM Damage State Description	Median	Rata	Freq	Low G	Function	Damage	LT_Cost	LT_Cost	Duration	SSC	SSC	SSC
1 Bushing Failure	1.50	0.30	33.00	0.35	1.0	0	1	\$2,000	\$100,000	0	0	0

Last Edit Date:

Count of times this record has been modified:

UpgradeCostSelection:

Total Items:



Anyone think this is a seismically-Robust rigid bus detail?

The bus "broke".


The breaker had to be replaced

Two adjacent positions "targeted"

Substation Name Abbr Substation_ID 566
Voltage 115 ComponentID 5223
Number Similar 1 Tag Number(s) 140 Latitude_DD 37.5010
Fragility ID 940 AA CB Longitude_DD -121.9860
SF6 Composite ABB Asea Brown Boveri

SERA_Position
SERA_T_Line Voltage 115 CircuitID
Description CB
Tie1_ID Tie2_ID Tie3_ID
Slack1 RB-Small 3-way Slack2 PGD Slack for Settlement

Photo1 Photo2 Photo3 Photo4 Photo5 Photo1_LR Photo2_LR Photo3_LR Photo 4_LR Photo 5_LR Site Map



buswork failed in 2007 EQ

Original Photo: 1024 w x 681 h Thumbnail Photo: 1024 w x 768 h

NFM	Damage	State	Description	Median	Beta	Freq	Low G	Function	Life Safety	Group	ST_Cost	LT_Cost	Duration	accDisp	SSG
1	Bushing	Failure		1.50	0.30	33.00	0.35	1.0	0	1	\$2,000	\$100,000	0	0	0



Description	Value	Comment
1. Count of Items	3,231,904	Includes non-exposed items
2. Count of Items	632,313	Exposed Items, 0.0001g to 1.00g
3. Max PGA level	0.87g	
4. Max PGA level (5 or more items)	0.87g	
5. Min PGA level with any type of damage	0.04g	
6. Item count with any type of damage	109	
7. Beta (composite)	0.6530	
8. Fragility (Median)	2.71g	Least Squares Regression
9. Fragility (Median)	1.80g	Running Pct weight



Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	210	0	0.32	0.32	0.32
230	2885	0	0.35	0.32	0.35
115	1856	0	0.32	0.32	0.32
69	0	0	0	0	0
LV	377	0	0.30	0.21	0.30

Table 5-3. Exposure and Damage Statistics, Air Core Reactors (AC)

Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	0	0	0	0	0
230	0	0	0	0	0
115	0	0	0	0	0
69	0	0	0	0	0
LV	4063	4	0.42	0.35	0.23

Table 5-4. Exposure and Damage Statistics, Buildings (BL)

Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	3312	0	0.33	0.32	0.33
230	9788	0	0.42	0.35	0.35
115	14390	1	0.38	0.35	0.04
69	9173	0	0.82	0.39	0.85
LV	468	0	0.25	0.25	0.25

Table 5-5. Exposure and Damage Statistics, Circuit Breakers (CB)

Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	1115	0	0.32	0.32	0.32
230	2328	0	0.35	0.35	0.35
115	1716	0	0.32	0.31	0.32
69	0	0	0	0	0
LV	0	0	0	0	0

Table 5-6. Exposure and Damage Statistics, Capacitors (CP)



Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	162	0	0.07	0.07	0.07
230	2586	3	0.35	0.35	0.33
115	7345	0	0.55	0.51	0.55
69	1803	0	0.35	0.35	0.35
LV	0	0	0	0	0

Table 5-7. Exposure and Damage Statistics, Circuit Switchers (CS)

Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	567	0	0.13	0.13	0.13
230	747	0	0.20	0.20	0.20
115	1004	0	0.33	0.33	0.33
69	96	0	0.31	0.30	0.31
LV	45	0	0.09	0.07	0.09

Table 5-8. Exposure and Damage Statistics, Current Transformers (CT)

Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	11395	18	0.33	0.33	0.31
230	110551	24	0.42	0.42	0.10
115	188334	3	0.55	0.55	0.10
69	100280	0	0.87	0.87	0.87
LV	201	0	0.26	0.34	0.25

Table 5-9. Exposure and Damage Statistics, Disconnect Switches (DS)

Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	0	0	0	0	0
230	0	0	0	0	0
115	0	0	0	0	0
69	0	0	0	0	0
LV	11121	0	0.87	0.52	0.87

Table 5-10. Exposure and Damage Statistics, Emergency Power (EG)



Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	230	0	0.24	0.05	0.24
230	468	0	0.33	0.19	0.33
115	60	0	0.33	0.10	0.30
69	0	0	0	0	0
LV	30	0	0.26	0.03	0.26

Table 5-15. Exposure and Damage Statistics, Reactors (RE)

Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	507	0	0.24	0.24	0.24
230	398	0	0.21	0.15	0.21
115	6738	0	0.35	0.35	0.35
69	0	0	0	0	0
LV	0	0	0	0	0

Table 5-16. Exposure and Damage Statistics, Risers (RS)

Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	1720	0	0.33	0.33	0.33
230	1277	0	0.35	0.32	0.35
115	1145	0	0.36	0.36	0.36
69	0	0	0	0	0
LV	0	0	0	0	0

Table 5-17. Exposure and Damage Statistics, Surge Arrestors (SA)

Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	0	0	0	0	0
230	0	0	0	0	0
115	66	0	0.02	0.02	0.02
69	52	0	0.19	0.07	0.19
LV	8170	0	0.42	0.42	0.42

Table 5-18. Exposure and Damage Statistics, Station Service (SS)



Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	785	10	0.33	0.33	0.23
230	4686	3	0.42	0.35	0.23
115	9578	2	0.55	0.41	0.09
69	13127	7	0.87	0.87	0.71
LV	8311	1	0.56	0.55	0.10

Table 5-19. Exposure and Damage Statistics, Power Transformers (TR)

Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	2860	9	0.33	0.33	0.31
230	22804	1	0.42	0.42	0.34
115	15315	0	0.35	0.35	0.35
69	568	0	0.34	0.34	0.34
LV	465	0	0.36	0.36	0.36

Table 5-20. Exposure and Damage Statistics, Voltage Transformers (VT)

Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	665	0	0.33	0.32	0.33
230	2883	0	0.42	0.35	0.42
115	595	0	0.30	0.28	0.30
69	64	0	0.34	0.29	0.34
LV	0	0	0	0	0


Table 5-21. Exposure and Damage Statistics, Wave Traps (WT)

Voltage (kV)	Items Exposed > 0.0001g	Number Damaged	Max PGA g	Max PGA-5, g	PGA below which there is no Damage, g
500	0	0	0	0	0
230	16	0	0.08	0.03	0.08
115	0	0	0	0	0
69	0	0	0	0	0
LV	17007	9	0.39	0.39	0.27

Table 5-22. Exposure and Damage Statistics, Other Equipment (XQ)



Air Core Reactors (AC)



Bin size = 0.01g






Figure 4-10.3. Number of exposures to various levels of PGA, Disconnect Switch Class





Figure 4-10.4. Number of exposures to various levels of PGA, Wave Trap Class

Bin size = 0.01g



230 - 500 kV Wave Trap, CCVTs



The Old CCVTs failed at PGA \sim 0.35g, but the WTs did not

New CCVTs: Median PGA = 1.46g, beta = 0.29.
Pretty darn tough.



F = had functional damage. D = had damage, but remained functional

SUMMARY over all records.		PGA Maximum 0.87 g	PGA Max-5 0.87 g	PGA CutOff 0.09 g	PGA CutOff 0.04 g	PGA CutOff 0.04 g	----- or lower -----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	Model Type ----	
PGA Bin Low	PGA Bin High	Count	Running Count	hasD Count	hasF Count	hasFD Count	hasD Count	Running Count	Running Count	Running Count	hasD pct	hasF pct	hasFD pct	hasD pct	hasF pct	hasFD pct	hasD pct	hasF pct	hasFD pct	-- FRAGILITY MEDIANS (in g)--	
																				-- D F FD	
0.0000 to 0.0001 g	2599591	3231904	0	0	0	51	58	109	0.0000000	0.0000000	0.0000000	0.0000158	0.0000179	0.0000337	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0 0 0
0.0001 to 0.01 g	366015	632313	0	0	0	51	58	109	0.0000000	0.0000000	0.0000000	0.0000807	0.0000917	0.0001724	0.1175	0.1154	0.1037	0.1175	0.1154	0.1037	1 1 1
0.01 to 0.02 g	104590	266298	0	0	0	51	58	109	0.0000000	0.0000000	0.0000000	0.0001915	0.0002178	0.0004093	0.2038	0.1989	0.1783	0.2038	0.1989	0.1783	1 1 1
0.02 to 0.03 g	34637	161708	0	0	0	51	58	109	0.0000000	0.0000000	0.0000000	0.0003154	0.0003587	0.0006741	0.2803	0.2739	0.2437	0.2803	0.2739	0.2437	1 1 1
0.03 to 0.04 g	27674	127071	0	0	0	51	58	109	0.0000000	0.0000000	0.0000000	0.0004014	0.0004564	0.0008578	0.3580	0.3489	0.3109	0.3580	0.3489	0.3109	1 1 1
0.04 to 0.05 g	16865	99397	0	1	1	51	58	109	0.0000000	0.0000593	0.0000593	0.0005131	0.0005835	0.0010966	0.4269	0.4177	0.3704	0.4269	0.4177	0.3704	1 1 1
0.05 to 0.06 g	17293	82532	0	0	0	51	57	108	0.0000000	0.0000000	0.0000000	0.0006179	0.0006906	0.0013086	0.4959	0.4848	0.4286	0.4959	0.4848	0.4286	1 1 1
0.06 to 0.07 g	11483	65239	0	0	0	51	57	108	0.0000000	0.0000000	0.0000000	0.0007817	0.0008737	0.0016555	0.5537	0.5420	0.4778	0.5537	0.5420	0.4778	1 1 1
0.07 to 0.08 g	8582	53756	0	0	0	51	57	108	0.0000000	0.0000000	0.0000000	0.0009487	0.0010603	0.0020091	0.6087	0.5963	0.5245	0.6087	0.5963	0.5245	1 1 1
0.08 to 0.09 g	4129	45174	0	0	0	51	57	108	0.0000000	0.0000000	0.0000000	0.0011290	0.0012618	0.0023908	0.6630	0.6481	0.5692	0.6630	0.6481	0.5692	1 1 1
0.09 to 0.10 g	5910	41045	1	0	1	51	57	108	0.0001692	0.0000000	0.0001692	0.0012425	0.0013887	0.0026313	0.7224	0.7058	0.6192	0.7224	0.7058	0.6192	1 1 1
0.10 to 0.11 g	4003	35135	4	3	7	50	57	107	0.0009593	0.0007494	0.0017487	0.0014231	0.0016223	0.0030454	0.7730	0.7539	0.6612	0.7730	0.7539	0.6612	1 1 1
0.11 to 0.12 g	3231	31132	0	0	0	46	54	100	0.0000000	0.0000000	0.0000000	0.0014776	0.0017345	0.0032121	0.8375	0.8109	0.7127	0.8375	0.8109	0.7127	1 1 1
0.12 to 0.13 g	5006	27901	0	0	0	46	54	100	0.0000000	0.0000000	0.0000000	0.0016487	0.0019154	0.0035841	0.8880	0.8584	0.7532	0.8880	0.8584	0.7532	1 1 1
0.13 to 0.14 g	2194	22895	0	0	0	46	54	100	0.0000000	0.0000000	0.0000000	0.0020092	0.0023586	0.0043678	0.9180	0.8881	0.7770	0.9180	0.8881	0.7770	1 1 1
0.14 to 0.15 g	2298	20701	0	0	0	46	54	100	0.0000000	0.0000000	0.0000000	0.0022221	0.0026086	0.0048307	0.9639	0.9303	0.8134	0.9639	0.9303	0.8134	1 1 1
0.15 to 0.16 g	1517	18403	0	0	0	46	54	100	0.0000000	0.0000000	0.0000000	0.0024996	0.0029343	0.0054339	1.0015	0.9694	0.8459	1.0015	0.9694	0.8459	1 1 1
0.16 to 0.17 g	963	16886	0	0	0	46	54	100	0.0000000	0.0000000	0.0000000	0.0027242	0.0031979	0.0059221	1.0457	1.0107	0.8804	1.0457	1.0107	0.8804	1 1 1
0.17 to 0.18 g	1628	15923	1	0	1	46	54	100	0.0006143	0.0000000	0.0006143	0.0028889	0.0033913	0.0062802	1.0942	1.0554	0.9189	1.0942	1.0554	0.9189	1 1 1
0.18 to 0.19 g	864	14295	0	0	0	45	54	99	0.0000000	0.0000000	0.0000000	0.0031480	0.0037775	0.0069255	1.1337	1.0893	0.9496	1.1337	1.0893	0.9496	1 1 1
0.19 to 0.20 g	1174	13431	0	0	0	45	54	99	0.0000000	0.0000000	0.0000000	0.0033505	0.0040205	0.0073710	1.1761	1.1314	0.9851	1.1761	1.1314	0.9851	1 1 1
0.20 to 0.21 g	1352	12257	0	0	0	45	54	99	0.0000000	0.0000000	0.0000000	0.0036714	0.0044056	0.0080770	1.2109	1.1631	1.0106	1.2109	1.1631	1.0106	1 1 1
0.21 to 0.22 g	312	10905	0	0	0	45	54	99	0.0000000	0.0000000	0.0000000	0.0041265	0.0049519	0.0090784	1.2373	1.1869	1.0308	1.2373	1.1869	1.0308	1 1 1
0.22 to 0.23 g	1060	10593	0	0	0	45	54	99	0.0000000	0.0000000	0.0000000	0.0042481	0.0050977	0.0093458	1.2850	1.2333	1.0702	1.2850	1.2333	1.0702	1 1 1
0.23 to 0.24 g	1679	9533	6	4	10	45	54	99	0.0035736	0.0023824	0.0059559	0.0047204	0.0056645	0.0103850	1.3075	1.2565	1.0870	1.3075	1.2565	1.0870	1 1 1
0.24 to 0.25 g	399	7854	0	0	0	39	50	89	0.0000000	0.0000000	0.0000000	0.0049656	0.0063662	0.0113318	1.3480	1.2726	1.1085	1.3480	1.2726	1.1085	1 1 1
0.25 to 0.26 g	399	7455	0	0	0	39	50	89	0.0000000	0.0000000	0.0000000	0.0052314	0.0067069	0.0119383	1.3863	1.3088	1.1386	1.3863	1.3088	1.1386	1 1 1
0.26 to 0.27 g	317	7056	3	0	3	39	50	89	0.0094637	0.0000000	0.0094637	0.0055272	0.0070862	0.0126134	1.4218	1.3423	1.1661	1.4218	1.3423	1.1661	1 1 1
0.27 to 0.28 g	511	6739	5	0	5	36	50	86	0.0097847	0.0000000	0.0097847	0.0053420	0.0074195	0.0127615	1.4860	1.3769	1.2056	1.4860	1.3769	1.2056	1 1 1
0.28 to 0.29 g	612	6228	7	0	7	31	50	81	0.0114379	0.0000000	0.0114379	0.0049775	0.0060283	0.0130058	1.5629	1.3979	1.2425	1.5629	1.3979	1.2425	1 1 1
0.29 to 0.30 g	932	5616	0	0	0	24	50	74	0.0000000	0.0000000	0.0000000	0.0042735	0.0050931	0.0131766	1.6737	1.4120	1.2808	1.6737	1.4120	1.2808	1 1 1
0.30 to 0.31 g	1055	4684	0	0	0	24	50	74	0.0000000	0.0000000	0.0000000	0.0051238	0.0060746	0.0157985	1.6604	1.3936	1.2638	1.6604	1.3936	1.2638	1 1 1
0.31 to 0.32 g	883	3629	7	10	17	24	50	74	0.0079275	0.0113250	0.0192525	0.0066134	0.0073779	0.0083913	1.6158	1.3494	1.2190	1.6158	1.3494	1.2190	1 1 1
0.32 to 0.33 g	834	2746	3	35	38	17	40	57	0.0035971	0.0419664	0.0455635	0.0061908	0.0074566	0.0087575	1.6899	1.3729	1.2510	1.6899	1.3729	1.2510	1 1 1
0.33 to 0.34 g	397	1912	7	0	7	14	5	19	0.0176322	0.0000000	0.0176322	0.0073222	0.0082615	0.0099372	1.6773	1.2078	1.5580	1.6773	1.2078	1.5580	1 1 1
0.34 to 0.35 g	626	1515	1	1	2	7	5	12	0.0015974	0.0015974	0.0031949	0.0046205	0.0053803	0.0079208	1.9158	1.8657	1.6931	1.9158	1.8657	1.6931	1 1 1
0.35 to 0.36 g	174	889	3	0	3	6	4	10	0.0172414	0.0000000	0.0172414	0.0067492	0.0074994	0.0112486	1.8097	1.9837	1.5990	1.8097	1.9837	1.5990	1 1 1
0.36 to 0.37 g	13	715	0	0	0	3	4	7	0.0000000	0.0000000	0.0000000	0.0041958	0.0055944	0.0097902	2.0730	1.9429	1.7019	2.0730	1.9429	1.7019	1 1 1
0.37 to 0.38 g	248	702	0	0	0	3	4	7	0.0000000	0.0000000	0.0000000	0.0042735	0.0056980	0.0099715	2.1200	1.9867	1.7397	2.1200	1.9867	1.7397	1 1 1
0.38 to 0.39 g	24	454	0	3	3	3	4	7	0.0000000	0.1250000	0.1250000	0.0066079	0.0088106	0.0154185	1.9696	1.8400	1.5999	1.9696	1.8400	1.5999	1 1 1
0.39 to 0.40 g	9	430	0	0	0	3	1	4	0.0000000	0.0000000	0.0000000	0.0069767	0.0092356	0.0093023	1.9958	2.5454	1.8633	1.9958	2.5454	1.8633	1 1 1
0.40 to 0.41 g	46	421	0	0	0	3	1	4	0.0000000	0.0000000	0.0000000	0.0071259	0.0092353	0.0095012	2.0357	2.5968	1.9001	2.0357	2.5968	1.9001	1 1 1
0.41 to 0.42 g	62	375	0	0	0	3	1	4	0.0000000	0.0000000	0.0000000	0.0080000	0.0092667	0.0106667	2.0264	2.5941	1.8885	2.0264	2.5941	1.8885	1 1 1
0.42 to 0.43 g	1	313	0	0	0	3	1	4	0.0000000	0.0000000	0.0000000	0.0095847	0.0091949	0.0127796	1.9884	2.5571	1.8508	1.9884	2.5571	1.8508	1 1 1
0.43 to 0.44 g	1	312	0	0	0	3	1	4													

SUMMARY for TYPE= CB	TOTAL	PGA	PGA	PGA	PGA	PGA	
VOLTAGE	Exposed	Damaged	MAX	MAX-S	Cutoff	Cutoff	Cutoff
CLASS	>0.0001g number	Dam/Func number	g	g	hasD g	hasF g	hasFD g
500 kV	3312	0	0.33	0.32	0.33	0.33	0.33
230 kV	9788	0	0.42	0.35	0.42	0.42	0.42
115 kV	14390	1	0.38	0.35	0.38	0.04	0.04
69 kV	9173	0	0.85	0.39	0.85	0.85	0.85
Low V	468	0	0.25	0.25	0.25	0.25	0.25


SUMMARY for TYPE= CB		PGA	PGA	PGA	PGA	PGA	PGA	PGA	PGA	PGA	PGA
		Max	Max-S	Max	Max-S	Max	Max-S	Max	Max-S	Max	Max-S
		0.33 g	0.32 g	0.42 g	0.35 g	0.38 g	0.35 g	0.85 g	0.39 g	0.25 g	0.25 g
		500 kV	500 kV	230 kV	230 kV	115 kV	115 kV	69 kV	69 kV	Low V	Low V
			Running		Running		Running		Running		Running
PGA Bin Low	PGA Bin High	Count	Count	Count	Count	Count	Count	Count	Count	Count	Count
0.0000 to 0.0001 g		16449	19761	46957	56745	69040	83430	42038	51211	1502	1970
0.0001 to 0.01 g		2370	3312	6181	9788	8442	14390	5744	9173	243	468
0.01 to 0.02 g		543	942	1650	3607	2610	5948	1461	3429	64	225
0.02 to 0.03 g		78	399	403	1957	648	3338	555	1968	32	161
0.03 to 0.04 g		135	321	310	1554	567	2690	379	1413	15	129
0.04 to 0.05 g		66	186	187	1244	479	2123	167	1034	22	114
0.05 to 0.06 g		3	120	282	1057	396	1644	163	867	22	92
0.06 to 0.07 g		45	117	192	775	234	1248	104	704	4	70
0.07 to 0.08 g		27	72	78	583	142	1014	103	600	20	66
0.08 to 0.09 g		3	45	50	505	47	872	50	497	18	46
0.09 to 0.10 g		9	42	82	455	109	825	51	447	2	28
0.10 to 0.11 g		0	33	40	373	64	716	53	396	0	26
0.11 to 0.12 g		0	33	49	333	46	652	44	343	0	26
0.12 to 0.13 g		21	33	31	284	69	606	28	299	4	26
0.13 to 0.14 g		0	12	4	253	89	537	33	271	0	22
0.14 to 0.15 g		0	12	22	249	96	448	21	238	0	22
0.15 to 0.16 g		0	12	14	227	70	352	12	217	0	22
0.16 to 0.17 g		0	12	5	213	15	282	21	205	0	22
0.17 to 0.18 g		0	12	7	208	12	267	17	184	2	22
0.18 to 0.19 g		0	12	20	201	5	255	11	167	0	20
0.19 to 0.20 g		0	12	18	181	12	250	11	156	2	20
0.20 to 0.21 g		0	12	4	163	29	238	6	145	0	18
0.21 to 0.22 g		0	12	0	159	12	209	6	139	0	18
0.22 to 0.23 g		0	12	44	159	5	197	9	133	0	18
0.23 to 0.24 g		0	12	47	115	29	192	10	124	0	18
0.24 to 0.25 g		0	12	0	68	3	163	7	114	18	18
0.25 to 0.26 g		0	12	0	68	20	160	4	107	0	0
0.26 to 0.27 g		0	12	0	68	8	140	11	103	0	0
0.27 to 0.28 g		0	12	0	68	4	132	7	92	0	0
0.28 to 0.29 g		0	12	7	68	4	128	26	85	0	0
0.29 to 0.30 g		0	12	9	61	37	124	12	59	0	0
0.30 to 0.31 g		0	12	2	52	14	87	7	47	0	0
0.31 to 0.32 g		9	12	4	50	10	73	0	40	0	0
0.32 to 0.33 g		3	3	33	46	42	63	7	40	0	0
0.33 to 0.34 g		0	0	3	13	2	21	8	33	0	0
0.34 to 0.35 g		0	0	8	10	18	19	8	25	0	0
0.35 to 0.36 g		0	0	0	2	0	1	9	17	0	0
0.36 to 0.37 g		0	0	0	2	0	1	0	8	0	0
0.37 to 0.38 g		0	0	0	2	1	1	2	8	0	0
0.38 to 0.39 g		0	0	0	2	0	0	2	6	0	0
0.39 to 0.40 g		0	0	0	2	0	0	0	4	0	0
0.40 to 0.41 g		0	0	0	2	0	0	2	4	0	0
0.41 to 0.42 g		0	0	2	2	0	0	0	2	0	0
0.42 to 0.43 g		0	0	0	0	0	0	0	2	0	0
0.43 to 0.44 g		0	0	0	0	0	0	0	2	0	0
0.44 to 0.45 g		0	0	0	0	0	0	0	2	0	0
0.45 to 0.46 g		0	0	0	0	0	0	0	2	0	0
0.46 to 0.47 g		0	0	0	0	0	0	0	2	0	0
0.47 to 0.48 g		0	0	0	0	0	0	0	2	0	0
0.48 to 0.49 g		0	0	0	0	0	0	0	2	0	0



Figure 5-1 shows a photo and SERA database record for FragilityID = 111.

Equipment Abbreviation	EQ	Voltage (kv)	0	Substation
Equipment Description	Desk top or other computer monitors (unanchored)			

Photo 1 Photo 2 Photo 3 Photo 1_LR Photo 2_LR Photo 3_LR



Fragility ID NFMODE Slack Frequency Hz

FIELD RATINGS		Rating Non-Transformer	
Anchorage Rating	<input type="text"/>	Radiator Rating	<input type="text"/>
Bushing High	<input type="text"/>	Surge Arrestor High	<input type="text"/>
Bushing Low	<input type="text"/>	Surge Arrestor Low	<input type="text"/>
Transformer Weight	<input type="text"/> pounds		
Self Supported Radiator Weight	<input type="text"/> pounds		
Anchor Description	<input type="text"/>		

Fragility Comments

PGE Book Number

BPA Book Number

BCH Book Number

SDGE Book Number

NFM	Damage State Description	Median	Beta	Freq Low	G	Function	Safety	Life	Group	ST Cost	LT Cost	Duration	acc/disp	SSG	DSC
1	Monitor falls to floor	0.35	0.30	33.0	0.10	1.0	0	1		\$1,000	\$2,000	0	0	0	0

PGA Bin (g)	Items Exposed Running Count	D No. Damaged and Functional	F No. Damaged and non-Functional	Fragility, D PGA (g)	Fragility, F PGA (g)
[1]	[2]	[3]	[4]	[5]	[6]
0.00	5276	3	0	-	-
0.01	1081	3	0	0.06	0.04
0.02	509	3	0	0.10	0.08
0.03	392	3	0	0.15	0.12
0.04	293	3	0	0.18	0.16
0.05	183	3	0	0.20	0.20
0.06	143	3	0	0.23	0.24
0.07	106	3	0	0.24	0.28
0.08	102	3	0	0.27	0.32
0.09	93	3	0	0.30	0.36
0.10	89	3	0	0.33	0.40
0.11	86	3	0	0.36	0.44
0.12	79	3	0	0.38	0.48
0.13	77	3	0	0.41	0.52
0.14	39	3	0	0.36	0.56
0.15	39	3	0	0.38	0.60
0.16	29	3	0	0.37	0.64
0.17	29	3	0	0.39	0.68
0.18	29	3	0	0.41	0.72
0.19	29	3	0	0.43	0.76
0.20	29	3	0	0.46	0.80
0.21	29	3	0	0.48	0.84
0.22	27	3	0	0.49	0.88
0.23	27	3	0	0.51	0.92
0.24	25	3	0	0.52	0.96
0.25	24	3	0	0.53	1.00
0.26	24	3	0	0.55	1.04
0.27	19	3	0	0.52	1.05
0.28	19	3	0	0.54	1.09
0.29	18	2	0	0.64	1.10
0.30	15	2	0	0.62	1.05
0.31	10	2	0	0.54	0.93
0.32	8	2	0	0.50	0.83
0.33	6	2	0	0.44	0.73
0.34	6	2	0	0.45	0.75
0.35	4	1	0	0.54	0.61
0.36	1	1	0	0.02	0.36
Fragility			Average	0.39	0.63
			Weighted	0.45	0.71
			Max	0.64	1.10

Figure 5-1. Desk Top Monitor Unanchored, Fragility Model 111



Equipment Abbreviation DS Voltage (kV) 230 Substation 43-2-44-3
 Equipment Description Post Insulator, Double height, Braced Frame, 2 stacks, Pacific Air Switch Corp circa 2002, Pasor



Fragility ID: 4 NMODE: 2 Stack Frequency: ED Hz

FIELD RATINGS

Rating Non-Transformer: Radistor Rating:
 Anchorage Rating: Surge Arrester High:
 Buckling High: Surge Arrester Low:
 Buckling Low:
 Transformer Weight: pounds
 Self-Supported Radistor Weight: pounds
 Anchor Description:

PGE Book Number:
 SFA Book Number:
 SOH Book Number:
 SOGE Book Number:

Fragility Comments:

Item	Median	Base	Frag Low G	Weighting	Plant	Age	ST Cost	LT Cost	Inventory	Program	Notes
1 Post Failure	1.00	0.50	20.0	0.40	1.0	1	\$7,000	\$10,000	0	0	0
2 Corrosion Insulator	1.80	0.50	30.0	0.25	1.1	1	\$1,000	\$1,000	0	0	0

Item	Value	Comment
FragilityID	4	The SERA FragilityID Number
Type	DS	Disconnect Switch
Voltage	230	kV
Item Count	20736	Total items
Count > 0.0001g	3663	Number of Items exposed to PGA > 0.0001g
Count > 0.05g	537	Number of Items exposed to PGA > 0.05g
Count > 0.10g	219	Number of Items exposed to PGA > 0.10g
Count > 0.20g	42	Number of Items exposed to PGA > 0.20g
Max PGA g	0.32g	Highest PGA level any item was exposed to
Max-5 PGA g	0.32g	Highest PGA level at least 5 items were exposed to
Count Damage	0	Number of items damaged and remained functional
Count FuncDam	0	Number of items damaged and not functional
Count F or D	0	Number of items damaged and either func. or non-func.
PGA Cutoff hasD, g	0.32g	Highest PGA level below which there was no damage
PGA Cutoff hasF, g	0.32g	Highest PGA level below which there was no func. damage
PGA Cutoff hasFD, g	0.32g	Highest PGA level below which there was no damage: f or non f
Fragility D, g	0.85g	Weighted fragility based on damage but functional
Fragility F, g	0.85g	Weighted fragility based on damage non-functional
Fragility FD, g	0.85g	Weighted fragility based on damage, functional or non-functional
Description		Post Insulator, Double Height, Braced Frame



IEEE 693 vs Reality

- IEEE 693 is geared to qualify equipment for $PGA = 0.50g$, with "margin"
- Margin is good. Otherwise, we get regular widespread failures
- A few failures in a single earthquake (earthquake sequence) is "acceptable".



Fragility Based on Test Data

Type	Voltage Class KV	Median PGA, g	Beta	Slack Frequency Hz
DS	500	1.01	0.43	3.0
SA	500	4.44	0.29	1.6
DS	500	0.95	0.43	2.7
CB	500	2.43	0.30	8.3
DS	500	1.49	0.38	4.3
CB	500	3.33	0.28	11.5
CB	500	3.33	0.28	7.8
CB	115	2.35	0.31	14.2
CB	230	2.71	0.31	6.3
CB	115	1.21	0.27	6.8
CB	115	1.70	0.30	6.8
CB	230	1.47	0.31	11.1
DS	230	1.29	0.29	5.0
CB	115	0.79	0.34	14.2
DS	500	1.21	0.29	2.6
CB	500	1.96	0.38	0.6
DS	230	1.91	0.29	
CS	115	1.46	0.29	
CS	115	1.29	0.29	
CS	230	1.90	0.29	
CS	60	1.72	0.29	
CS	115	1.82	0.29	
DS	500	1.14	0.29	4.8
CB	230	1.08	0.31	3.9
CB	230	1.29	0.31	6.8
CB	115	1.25	0.34	10.3
DS	500	1.97	0.29	2.9
DS	500			4.0
CB	500	1.25	0.27	
DS	230	0.43	0.35	7.5
DS	230	2.27	0.29	5.7
DS	230	6.09	1.04	7.0
DS	230	1.82	0.29	4.1
CB	230	2.96	0.31	3.4
DS	500	1.16	0.27	2.6
SA	500	6.02	0.29	1.6
CB	115	1.68	0.31	7.3
CB	60	2.53	0.31	19.5
CB	115	1.65	0.31	2.3
CB	115	1.02	0.31	14.2

Type	Voltage Class KV	Median PGA, g	Beta	Slack Frequency Hz
CB	230	2.71	0.31	3.1
CB	230	1.96	0.37	5.5
SA	230	6.83	0.30	3.1
CB	115	0.88	0.31	6.6
DS	500	1.38	0.29	2.5
SA	500	1.17	0.29	2.0
CB	115	1.37	0.31	7.7
CB	500	1.71	0.28	6.0
DS	115	3.99	0.35	8.3
CB	34	1.05	0.34	5.3
DS	115	4.59	0.35	8.4
DS	500	1.78	0.29	3.5
DS	115	8.07	0.35	10.1
CB	500	1.81	0.35	0.9
DS	500	2.97	0.29	4.3
CB	60	1.41	0.31	7.4
CB	115	1.61	0.31	7.7
CB	230	2.75	0.31	4.7
DS	500	1.84	0.29	3.4
CB	60	1.55	0.34	8.0
DS	500	2.97	0.29	4.3
SA	230	2.95	0.29	3.9
DS	230	1.50	0.29	8.0
CS	500	1.49	0.29	2.7
DS	230			
DS	500	0.92	0.42	6.2
DS	500	1.08	0.29	2.5
DS	500	0.94	0.29	1.8
DS	500	0.95	0.29	1.8
PH	115	0.55	0.29	
PH	230	0.28	0.29	
CB	230	3.03	0.31	3.3
CB	60	1.14	0.34	21.9

Modern, mostly post IEEE 693



Component	34 kV	60 kV	115 kV	230 kV	500 kV
CB	1.05	1.66	1.41	2.22	2.26
CS		1.72	1.52	1.90	1.49
DS			5.55	2.19	1.49
PH <small>pre-IEEE 693</small>			0.55	0.28	
SA				4.89	3.88

Average PGA Fragility levels (Medians)




The Elephant in the Room



Can SERA Reasonably Predict Power Outages?


SERA Forecast vs Actual, 12 M 6+ Earthquakes



Regression line: nearly a 1:1 slope



Fragility of Overhead Feeders



This reflects 25 years of data collection!



Some data from Ridgecrest 2019

- July 4. M 6.4. 49 incidents. 19,501 customers lose power. CM = 16.1 Million
- July 5. M 7.1. 87 incidents. 17,808 customers lose power. CM = 19.4 Million
- In comparison. Winter storm: 200 Million CM (1+ times per year). High wind event: 500 Million CM (1 time per century). M 7 Earthquake: 1 Billion CM. M 8 Earthquake: 5 Billion CM (?)
- What's acceptable in California?
 - 40 Million to 100 Million CM: customers generally satisfied.
 - 500 Million CM: some customers angry.
 - 5 Billion: politics takes over, anything can happen.



Date	Time	Crew Size	Crews Needed	Duration Hrs	Man hours	Damage Summary
07/19/2019	13:25:00	4	1	4	16	Wire Stripped to Steel Core
07/06/2019	8:58:00	4	1	8	32	Cross-Arm
07/04/2019	18:31:00	4	1	4	16	Cross-Arm
07/22/2019	10:23:00	4	1	4	16	Cross-Arm
07/06/2019	5:12:00	4	1	8	32	Cross-Arm
07/06/2019	4:09:00	4	1	4	16	Cross-Arm
07/06/2019	12:17:00	4	1	10	40	Transformer / Fire
07/06/2019	2:12:00	4	1	8	32	Leaning Pole / Replaced Pole
07/06/2019	6:13:00	4	1	16	64	Broken Tap
07/07/2019	17:09:00	4	1	6	24	Birdcage / Flashover / Broken Insulator
07/05/2019	13:30:00	1	1	1	1	Pri. Wire Down
07/06/2019	1:30:00	4	1	8	32	Pri. Wire Down
07/06/2019	23:50:00	4	1	4	16	Replace Street Light Pole
07/07/2019	20:01:00	5	1	1	5	Transformer
07/10/2019	7:08:00	4	1	8	32	UG Sec. Damaged
07/07/2019	21:52:00	4	1	6	24	Transformer
07/05/2019	15:36:00	4	1	8	32	UG Sec. Damaged
07/08/2019	11:33:00	4	1	8	32	Broken Insulator / Flashover
07/30/2019	12:25:00	1	1	4	4	Equipment Twisted / Repaired
07/08/2019	12:25:00	4	1	4	16	Sec. Wire Down
07/06/2019	19:10:00	4	4	5	80	Leaning Pole / Repair Pole
07/04/2019	14:45:00	1	1	1	1	Pri. Wire Down/ Cross-Arm
07/05/2019	15:14:00	5	1	8	40	Pri. Wire Down

Remote area. Might be EQ-related



3 Transformer Frames: High W, Low Frequency, High Wire “snapping” forces, High Torsion = high displacement demand on drop wires



Tilted Poles



Birdcaging



Why: high curvature. What causes the high curvature: cable galloping dynamics



Insulators



Replaced

Why: high conductor forces. If copper wires, wires can break.
If ASCR wires (aluminum with steel core), the conductor is so strong, the insulator breaks.
Or, sometimes the cross arm breaks.

Root cause: no seismic design to determine forces in wires and limit forces to allowable



Street Lights



Replaced



Not Replaced




Located < 100 meters away



Inertial loading. Why? ShakeMap shows PGA 0.28g constant for both these poles. Most likely, this was not the case, and PGA (spectra) was $\gg 0.28g$. (or, did local Dogs weaken these poles?). Corrosion is KING



Wire Down



Wire Test Data



Copper Wires: Break forces around 1,200 pounds. Non-ductile, Strain at failure ~ 2%
Aluminum wires: Non-ductile if using electrical-grade aluminum



Cross Arms



Cross Arms



Older Transformers hooked onto Cross Arms
Not many of these left....



Wrapped Wires



Secondary neutral wrapped around an energized phase leading to burn down.



Cable / Pole Snapping Forces



Trends

- Rate of failures much higher if poles are in liquefied zones
- Drop span poles (lots of sag to produce zero forces under normal conditions) have much higher rates of repairs
- Phase-to-phase causes momentary outages (commonly a few seconds), or opens a breaker (recloser) requiring inspection before re-energizing, or opens a fuse or causes an entanglement / burn down, requiring repair.
- Fragility: PGA, PGV, SA($T=3.0$ seconds).



Summary

- SERA - ShakeMap. These tools can predict power outages. All you need is inventory, fragility, hazards.
- Substations. The problem is largely "solved". Some utilities implement. Others are waiting for that 66 million year event
- 475, 975, 2475 years "code-probabilistic". These are actually 3, 4, 7 years "reality" for a large geographic area.
- \$300 Billion will reduce power outages by 90%. Maybe SERA - ShakeMap tools can do this "smarter"



Thank you

