

Seismic Performance of Water Pipelines in the August 24 2014 Napa Earthquake

John Eiding
eidinger@geEngineeringSystems.com

JWWA-WRF-CTWWA Workshop, Sendai, October 2015

Place Names and Populations


■ Urban Areas (est. population as of June 2014, or latest data)

SERA 8.4.3.3 Third Shakemap, PGA (g), Max of NS, EW

SHAKEMAP EARTHQUAKE
ID= 72202711
Magnitude = 6.00
Factored by 1.00
PGA-g

0.70 +	Red
0.55 - 0.70	Blue
0.40 - 0.55	Green
0.25 - 0.40	Magenta
0.20 - 0.25	Grey
0.15 - 0.20	Cyan
0.10 - 0.15	Yellow
0.05 - 0.10	Light Grey

Scale: (Meters per inch)
One inch = 12444.
Meters/Pixel = 132.





The City of Napa.

M 6.0 Earthquake on West Side of Town


Population 77,000 people

337 Miles (540 km) of Water Pipes, 164 Repairs.

~ Same Length of Gas Pipes, 0 Repairs.
(but some replacement of gas pipes
that crossed the fault after the earthquake)

Why?

164 Water Pipe Repairs




Elevation, Feet

0 - 100
100 - 200
200 - 300
300 - 400
400 - 500
500 - 600
600 - 4500


Location of Water Pipe Repairs •




Why were there so many Pipe Failures?



164 Water Pipe Breaks: Plotted by Pipe Material



164 Water Pipe Breaks: Plotted by Pipe Diameter




Total Pipe Repairs, By Sept 15 2015 (add 50% Sept-Jan 2015)

Material	Repairs	% Repairs	% Pipe	Repair per Mile
AC	8	5%	10%	0.23
PVC	2	1%	2%	0.34
CI	123	75%	44%	0.82
DI	18	11%	34%	0.16
Steel	3	2%	9%	0.10
Other / unk	7	4%		
Total	163	100%		

Total Pipe Length, 337 Miles

Age (years)	PVC	DI	CI	AC	RCCP	STL	Total	Pct of Total
< 20	6,600	225,600				100	232,300	13%
20-40	24,300	370,500	83,400	14,100		100	492,400	28%
40-60		12,300	466,700	167,200	9,900	59,800	715,900	40%
60-80			173,100			100,400	273,500	15%
80-100			55,100				55,100	3%
> 100			10,300				10,300	1%
Total	30,900	608,400	788,500	181,300	9,900	160,400	1,779,500	100%
	2%	34%	44%	10%	1%	9%	100%	

Length of Pipe in Napa Water System (2012, feet)



Total Pipe Repairs, By Sept 15 2015 (add 50% Sept-Jan 2015)

Material	Repairs	% Repairs	% Pipe	Repair per Mile
AC	8	5%	10%	0.23
PVC	2	1%	2%	0.34
CI	123	75%	44%	0.82
DI	18	11%	34%	0.16
Steel	3	2%	9%	0.10
Other / unk	7	4%		
Total	163	100%		

Total Pipe Length, 337 Miles

Age (years)	PVC	DI	CI	AC	RCCP	STL	Total	Pct of Total
< 20	6,600	225,600				100	232,300	13%
20-40	24,300	370,500	83,400	14,100		100	492,400	28%
40-60		12,300	466,700	167,200	9,900	59,800	715,900	40%
60-80			173,100			100,400	273,500	15%
80-100			55,100				55,100	3%
> 100			10,300				10,300	1%
Total	30,900	608,400	788,500	181,300	9,900	160,400	1,779,500	100%
	2%	34%	44%	10%	1%	9%	100%	

Length of Pipe in Napa Water System (2012, feet)

Sandybrook Lane

Meadowbrook Lane

White Cliff Circle


Twin Oaks Drive

Primary Offset Zone (Line A)



Ground Shaking, PGV


10-20




Water Pipe Repair Status




PGV, cm/sec




ShakeMap Level of Shaking








Pipe Damage +
Fault Offset Zone A



29

121



W. Imola

Pipe Damage +
Liquefaction Zone B

12

29

Water Pipe Repair Status




Observed Locations of Surface Faulting





Pipe Damage +
Fault Offset Zone A





Pipe Damage +
Liquefaction Zone B

Liquefaction Susceptibility

- Very high
- High
- Moderate
- Low
- Very low
- Not mapped
- Water


West Side
Reservoir

W. Imola

Water Pipe Repair

- Pipe Repair





West Side Reservoir



Previously Mapped Liquefaction Susceptibility


- Very high
- High
- Moderate
- Low
- Very low
- Not mapped
- Water

Water Pipe Repair

- Pipe Repair

- ★ Liquefaction Effect Observations

Pipe Damage + Liquefaction Zone B



Location 1. Hilltop Drive

Residential Construction
1950s Vintage



Road Entirely Resurfaced After September 2014
Pipe Repair Post October 2014

Location 2. Mannering Street

Residential Construction
1950s Vintage



Road Entirely Resurfaced After September 2014
Pipe Repairs Post October 2014

Location 3. Mannering Street



Unreinforced concrete patio
Cracks due to differential settlements



Location 4. Mannering Street


Unreinforced concrete driveway
Cracks due to differential settlements
Water table confirmed, <5 feet
(Tree in planter box is about to be moved)

Location 5. Cypress Street



Looking West.
Road entirely re-surfaced

Location 6. Cypress Street



Looking East.
Road entirely re-surfaced
Bruce Maison Standing over Recent Pipe Repair

Location 7. Cypress Street



Looking South

Location 8. Cypress Street



Looking South

Location 9. Hilltop at DeVita Street



Location 10. West Side Reservoir



Looking North

PGV

	<i>20-30 cm/sec</i>	<i>30-40 cm/sec</i>	<i>40-50 cm/sec</i>	<i>50-60 cm/sec</i>	<i>60-70 cm/sec</i>	<i>70-80 cm/sec</i>	<i>80-90 cm/sec</i>	<i>Total</i>
<i>AC</i>					2	2	3	7
<i>CI</i>	3		2	16	38	41	10	110
<i>DI</i>				2	4	4	7	17
<i>PVC</i>					2			2
<i>STL</i>					1	1		2
<i>UNK</i>	3	1	2	1	9	7	2	25
<i>Total</i>	7	1	4	19	56	55	22	164

Pipe Repairs versus level of PGV, (Through Sept 15)

Number of Pipe Repairs Versus Mapped Liquefaction Susceptibility

	<i>Very Low</i>	<i>Low</i>	<i>Low- Moderate</i>	<i>Moderate</i>	<i>None</i>	<i>Total</i>
<i>AC</i>			1	5	1	7
<i>CI</i>	0	11	28	48	23	110
<i>DI</i>	2	1	4	6	4	17
<i>PVC</i>	1				1	2
<i>STL</i>				1	1	2
<i>UNK</i>	1	1	1	3	19	25
<i>Total</i>	5	13	34	63	49	164

But, some of the pipes in the yellow (moderate) boxes in fact had fairly widespread liquefaction. Field work showed: widespread soil movements (typically 1 inch or so) and very high surface water table in soils deposited in a drainage area. This area was incorrectly mapped in USGS with a low ground water table (>10 feet), but in fact has a ground water table < 5 feet from the surface.

Breakdown of actual pipe damage in Napa Earthquake

Pipe Type	Length, System-wide (miles)	Repairs due to Shaking (PGV)	Repairs due to Liquefaction (PGD)	Repairs due to Surface Faulting (PGD)	Total Repairs, August 24 to Sept 15 2014
AC	34.34	2	0	5	7
CI	149.34	86	19	5	110
DI	115.23	8	4	5	17
PVC	5.85	2	0	0	2
STL	30.38	2	0	0	2
RCCP	1.88	0	0	0	0
UNK		22	0	3	25
Total	337.01	122	23	18	163

ALA (2001) Models

$$RR = k1 * 0.00187 * PGV \text{ (shaking)}$$

$$RR = k2 * 1.06 * PGD^{0.319} \text{ (liquefaction, landslide)}$$

RR = Repair Rate per 1,000 feet (highest of two calculations)

PGV = Peak Ground Velocity (inches per second)

PGD = Permanent Ground Deformation (inches)

Updated (2015) Models

$$RR = k1 * k2 * k3 * 0.00187 * PGV \text{ (shaking)}$$

$$RR = k1 * k2 * k3 * 1.06 * PGD^{0.319} \text{ (liquefaction, landslide)}$$

RR = Repair Rate per 1,000 feet (highest of two calculations)

PGV = Peak Ground Velocity (inches per second)

PGD = Permanent Ground Deformation (inches)

Comparison, Updated (2015) and ALA (2001) Models

Updated 2015

ALA 2001

PGV

Pipe Type	k1 corrosion	k2 diameter	k3 material	k1 ALA 2001
AC	1.0	1.0	0.3	0.5
CI assume Rho = 1000, age = 1930	2.5	1.0	1.0	1.0
DI assume Rho = 2000, age = 1940	1.5	1.0	0.3	0.5
PVC	1.0	1.0	0.3	0.5
STL	1.0	1.0	0.7	0.7
RCCP	1.0	1.0	0.2	0.2

Metal Pipes. Rho < 1500 ohm-cm. Age < 1920. k1 = 3.0. Post 1960. k1 = 1.0. 1920-1960 interpolate

Metal Pipes. Rho 1500 to 2500 ohm-cm. Age < 1920. k1 = 2.0. Post 1960. k1 = 1.0. 1920-1960 interpolate

Metal Pipes. Rho > 2500 ohm-cm. k1 = 1.0

PGD

Pipe Type	k1 corrosion	k2 Diameter (≤ 12 inches)	k3 material	k1 ALA 2001
AC	1.0	1.0	0.8	0.8
CI	1.0 (0.8)	1.0	1.0	1.0
DI	1.0 (0.8)	1.0	0.5	0.5
PVC	1.0	1.0	0.8	0.8
STL	1.0 (0.8)	1.0	0.7	0.7
RCCP	1.0	1.0	0.7	0.7

Metal Pipes. Rho < 1500 ohm-cm. k1 = 1.0

Metal Pipes. Rho > 1500 ohm-cm. k1 = 0.8

All pipe types on this page have push-on / cemented joints, unrestrained.

CI, DI pipes have no special corrosion protection.

No pipes use GENEX or similar.

Breakdown of pipe damage in Napa Earthquake
due to Shaking (no liquefaction, no surface faulting)

Pipe Type	Length, System-wide (miles)	Actual Repairs due to Shaking	Forecast Repairs due to Shaking
AC	34.34	2	2.4
CI	149.34	86	88.5
DI	115.23	8	12.3
PVC	5.85	2	0.4
STL	30.38	2	5.0
RCCP	1.88	0	0.1
UNK		22	
Total	337.01	122	108.8

With Updated
Seismic Models

Breakdown of pipe damage in Napa Earthquake
due to Liquefaction

Pipe Type	Length, System-wide (miles)	Actual Repairs due to Liquefaction	Forecast Repairs due to Liquefaction
AC	34.34		
CI	149.34	19	21.2
DI	115.23	4	4.3
PVC	5.85		
STL	30.38		
RCCP	1.88		
UNK		0	
Total	337.01	23	25.5

With Updated
Seismic Models

Pipe Fragility Models - Lessons Learned from Napa

- The updated (2015) pipe fragility models provide very good forecasts of the pipe damage.
 - Napa has VERY corrosive soils. This explains some of the high failure rates seen in August 2014.
 - Napa did have Liquefaction. This explains some of the high failure rates.
 - Damage of water pipes due to surface faulting (<15 cm) was modest.

Pipe Fragility Models - Lessons Learned from Napa

- Gas pipelines had ZERO pipe failures in this earthquake. Water pipes had 164 failures.
- Gas pipelines used either heavy wall welded steel pipes (transmission) or MDPE pipes (distribution).
- ZERO Pipe failures (gas) versus 164 pipe failures (water), for pipes exposed to the same PGV and PGD.
- Aggressive soils ($Rho < 1,500$ ohm-cm) explains a LOT of the cast iron and ductile iron (without special corrosion protection) water pipe failures.

Questions?