

Power Outages,
December 20 2022 M 6.4 Fortuna Earthquake

John Eiding, S.E.

Copyright G&E Engineering Systems Inc. 2023

71,236 Customers \approx 100% of PG&E electric customers in Eureka, Arcata, McKinleyville, Samoa Peninsula, Fortuna, Rio Dell, Trinidad, plus some in Garberville / Ukiah and outlying areas




Area under red curve: \sim 79,000,000 Customer-Minutes

This is similar to outages that happen 2-5 times per year due to winter storms in Northern California

Power Outages

- What caused these power outages? (by CM percentage)
- 5%: 37 repairs on overhead 12 kV wire systems (wire down, cross arms, etc.). Dominant failure mode is broken copper wires due to wood pole swaying
- 95%: phase-to-phase and phase-to-ground faults due to wire swaying, in 12 kV, 60 kV and 115 kV systems (2 repairs on overhead 115 kV wire systems). 98% of these types of faults: no damage found by patrols.


60 kV - 12 kV Transformers (TR). B, C, Spare had failed anchorage.
PGA (median) = 0.50g (attenuation based).
PGA (range) = 0.32g to 0.77g; 16th to 84th.
These transformers were installed in 1949.
1949-era anchorage design $V \approx 0.25W$.




Modern (IEEE 693 1997 and later) anchorage design is $V \sim 1.0W$ (elastic).
No modern designs failed at 18 substations with $0.10g \leq PGA \leq 0.50g$.
Adjacent transformer bank had no damage, and carried all the load.
Due to redundancy, this damage caused zero power outages.



Bolt stretched, plate pried,
web buckled



Bolt broke, TR slid ~1 inch,
web buckled



Bolt yielded, web buckled
(Ruler units are inches)

NOTICE TO CALIFORNIA, OREGON,
WASHINGTON, UTAH, ALASKA POWER UTILITIES

SOME OF YOU MAY STILL HAVE
WEAKLY-ANCHORED OR UNANCHORED TRANSFORMERS.
GET THESE UPGRADED!

Key findings

- Primary cause of widespread outages was wire swaying in 60 kV to 115 kV overheads.
- Primary cause of local outages was wire swaying in 12 kV overheads.
- Duration of outages primarily reflects time needed to do patrols. Most (not all) patrols found no damage.
- 79 million CM outage was like a big winter storm.
- Biggest seismic power outage in PG&E system since 1989 Loma Prieta (~1 billion CM)

Key findings

- IEEE 693 design (post 1997): zero damage to any substation component in this earthquake. Design anchorage elastically for $PGA \geq 0.50g$. 100% SUCCESS
- Transformer Anchorage. $V = 0.25W$ is not good enough.
- Unanchored transformers is sub-standard.
- $I = 1.0$ or $I = 1.5$ design at power plants (475 or 2,475 year design): makes no difference in outages or restoration of power in this earthquake, or >25 other California earthquakes since 1952.