

Napa Earthquake of 8.24.2014 Performance of Lifelines

Water, Power, Gas, Fires

What does it mean for the Peninsula?
Is Pipe Replacement in Our Future?


City and County Engineers Association of
San Mateo County

Iron Gate Restaurant, Belmont, CA, March 17 2016


John Eiding
G&E Engineering Systems Inc.
eidinger@geEngineeringSystems.com

Damaged Pipes in the Loma Prieta 1989 Earthquake for Selected Water Systems

- Damaged Cast Iron Pipe
- Damaged AC Pipe
- Damaged ABS Pipe
- Damaged PVC Pipe
- Other damaged pipe



Note: not all pipe repairs shown.
City of Santa Clara pipe repairs not shown.



Deliver 146 MGD or Higher within 24 hours

BDPL 4: 68% Reliable
 BDPL 3: 87% Reliable
 BDPL 3+4 with Crossovers: 97% Reliable
 Expected Major Repairs: 0 or 1 (requires immediate shutdown)
 Expected Leaks: 2-3 (delayed shutdown)

Note: Assumes Liquefaction Hazard is Mitigated or is a Negligible Risk

Legend	Abbreviations	General Notes	Earthquake Scenario: San Andreas M 7.9
<ul style="list-style-type: none"> Raw Water Reservoir Potable Water Reservoir Pump Station (Capacity in MGD) Pipeline Tunnel Valve Water Treatment Plant Emergency Bypass Outlet on Pipeline Pressure Reducing Valve To CDD Distribution System 	<ul style="list-style-type: none"> P/L Pipeline BDPL Bay Division Pipeline CS2 Crystal Springs #2 Pipeline CS3 Crystal Springs #3 Pipeline CS3X Crystal Springs #3 Extension P/L Elev Elevation ID Inside Diameter (inches) MG Million Gallons MGD Million gallons per Day PAPL Palo Alto Pipeline PCCP Prestressed Concrete Pipe PS Pump Station Res Reservoir SA1 San Andreas #1 Pipeline SA2 San Andreas #2 Pipeline SA3 San Andreas #3 Pipeline WTP Water Treatment Plant 54" 54 inch diameter 	<p>Pipes are shown schematically Elevations shown are approximate All raw water reservoirs are drawn to correct elevation (or with elevation shown) Potable water reservoirs are shown to correct elevation; except Summit, Sutro, MacLaren, College Hill, Stanford Heights, which are shown to very approximate elevation Pipelines shown are those in service as of 2000 Portions of CS1, SA1 which are out of service not shown</p>	<ul style="list-style-type: none"> X Component Failure, no specific estimated time to make repairs X² Component Failure, with estimated time in days to make temporary repairs to restore functionality X[?] Possibility of component failure X^{indef} Component failure with indefinite repair time (could be 1 year or longer) <p>Notes: Projected damage to CDD not shown. Damage pattern based on Phase II Regional System Overview & Reliability Response Report, Jan 21, 2000.</p>

SFPUC WATER SYSTEM

**San Andreas M 7.9
Damage Pattern**

	G&E ENGINEERING SYSTEMS, INC.	2/12/03
--	-------------------------------------	---------


San Andreas M 7.9

Good news: The 97% figure assumed good quality construction. Something has been done to address the "X" points
 Bad news: BDPL 1, 2, 5 may have weld problems. Portions of BDPL 1, 2 have been retired. Water rates are high.


Distribution weaknesses are not addressed by the SFPUC. Unknown hazards likely exist.

AS of 2016, the 97% figure is probably lower.

Water Systems in San Mateo County and Nearby (BAWSCA)



Water Systems with Earthquake Risk Assessment by G&E in San Mateo County and Nearby (BAWSCA)



Also: EBMUD, SCVWD, SFPUC, Zone 7. About 100 water systems from Canada to Mexico

Item	EBMUD	SFPUC + 20 Suburban Customers
Miles of Transmission Pipes	200	220
Miles of Distribution Pipes	3,900	3,700
Tunnels	16	20
Treatment Plants	6	8
Storage Tanks	175	202
Pump Stations	125	157
Small Pipes crossing active faults (<18")	178	66
Large pipes crossing active faults (≥20")	27	11
Tunnels crossing active faults	2	0
Pipe repairs, Loma Prieta 1989 EQ	~135	~400
Pipe Repairs, San Andreas M 7.9	< 1,000	1,190 to 3,030
Pipe Repairs, Hayward M 7.1	3,300 to 5,000	920 to 2,580

Item	EBMUD	SFPUC + 20 Suburban Customers
Seismic Upgrade, Transmission System	\$140 million	\$2,000 million
Seismic Upgrade, Distribution System	\$100 million	\$75-\$100 million
Seismic Improvements, Total (plus dams)	\$240 million	\$2075 to \$2100 million
Ratio, Distribution Costs to Total Costs	42%	4% to 5%
Population Served	1,300,000	2,500,000
Cost per person	\$185	\$840

EBMUD: includes Mokelumne Aqueduct Upgrades
SFPUC: a portion of \$4.7 Billion Reliability Upgrades

Water Distribution Pipes

- EBMUD: excludes money for pipe replacement
- SFPUC: excludes money for pipe replacement
- Pipe replacement: This is the ELEPHANT in the room



Replacing Seismically-Weak and Aging Water Pipes

The ELEPHANT in the room

ASCE's Viewpoint

- Aging Infrastructure
- Score Card: D- to C-
- Is this Rational, Silly, or what?

Why Replace Pipes?

- 
- Cause 1. Pipes leak! Aging, Corrosion, Earthquake, etc.
 - Cause 2. Relocations (new highway, etc.)
 - Cause 3. Growth. Flow rate of an older 4" pipe no longer meets modern flow requirements
- 
- Cause 4. After earthquakes, either patch the leaks (sporadic) or replace (severe damage)


Japan and USA Practices

- Japan: All (most) water pipes are replaced after about 65 years. JWWA / DI manufacturers seem to set the rules. Customers pay.
 - Everyone is happy.
- USA. No water pipes are replaced until they are leaking like sieves. If asked, Customers say no. If asked, FEMA (often) says no.
 - Everyone is unhappy.

The Big Question

- My pipes (Cast Iron) are 50 to 90 years old.
- My pipes (Asbestos Cement) are 35 to 60 years old.
- Many of them are at the end of their lives (or so one might think).
- I need a rate increase of 30% in order to replace them on a 100 year cycle.
- How do I convince the Board / City Council / customers to accept this rate increase?

Pipe Repairs - EBMUD (11,500 Repair Database)




EBMUD: 0.20 repairs / mile per year

Burbank:
Home of
Movies!

105,000
people

500 km of
water pipes


85% are “old”
Cast Iron
Pipes
(1910-1930)



City of Burbank Leak History
All Leaks

Burbank Leak History


Industry Average: 0.24 to 0.27



No trend for increasing leak rate in past 24.5 years


excludes leaks on service laterals

Redwood City Cast Iron Pipe



Palo Alto

Pipe Repairs in Year, 1990-2014




Corrosion

- Does soil resistance (Rho, ohm-cm) have influence over leak rates for metal pipes?
- Measure Rho
- Correlate Rho versus historical leak rate


Performed soil resistivity testing at various locations in Palo Alto

Rho value interpretation:

- $R = 500$ to $1,500$ ohm-cm. Extremely corrosive.
- $R = 1,500$ to $3,000$ ohm-cm. Highly corrosive.
- $R = 3,000$ to $5,000$ ohm-cm. Corrosive.
- $R = 5,000$ to $10,000$ ohm-cm. Moderately corrosive.
- $R = 10,000$ to $20,000$ ohm-cm. Mildly corrosive.
- $R > 20,000$ ohm-cm. Essentially non-corrosive.



Miles of Pipe vs Soil R



Leak Model. $RR = k_1 * k_2 * k_3$

Type / Diameter	CCP, RCP	HDPE	CI	CU	DI	GLV	SS, STL (≤12")	STL (>12")	UNK
Any	0.015	0.010	0.030	0.150	0.015	0.600	0.500	0.015	0.070
1" to 2"		0.010	0.400	0.150	0.015	0.600	0.500		0.400
4"		0.010	0.150		0.015	0.600	0.500		0.150
6"		0.010	0.030		0.015		0.500		0.070
8" – 12"	0.015	0.010	0.020		0.015		0.500		0.050
16" – 30"	0.015	0.010	0.020		0.015			0.015	0.015

k_1 Matl,
Diam

Type / Age (Years)	CCP, RCP	HDPE	CI	CU	DI	GLV	SS, STL (≤12")	STL (>12")	UNK
Any	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
0 to 20	0.90	0.95	0.90	0.75	0.80	0.80	0.80	0.90	0.90
20 to 40	1.00	1.00	0.95	1.00	1.00	1.00	0.90	0.95	1.00
40 to 60	1.10	1.05	1.00	1.25	1.10	1.00	0.95	1.00	1.00
60 to 80	1.15	1.10	1.25	1.50	1.15	1.20	1.00	1.00	1.10
80 to 100	1.20	1.15	1.50	2.00	1.25	2.00	2.00	1.10	1.15
100 +	1.50	2.00	2.00	2.50	2.00	2.50	2.50	1.30	

k_2 Age

Type / Resistance (Ohm-cm)	CCP, RCP	HDPE	CI	CU	DI	GLV	SS, STL (≤12")	STL (>12")	UNK
Any	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
1500-3000	1.50	1.00	1.50	2.00	1.25	2.00	2.00	1.25	1.25
3000-5000	1.10	1.00	1.10	1.25	1.10	1.25	1.25	1.10	1.10
5000-10000	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
10000-20000	0.90	1.00	0.90	0.90	0.90	0.90	0.90	0.90	0.90
20000+	0.90	1.00	0.90	0.90	0.90	0.90	0.90	0.90	0.90

k_3 R

Applicability:
Granular Soils

Different for
Clay Soils

k_I Factors (Material + Diameter)

k_I = Base rate * Factor

Example for 4" CIP: k_I = 0.112 * 1.4 = 0.157

(repairs / mile / year)

Base Rate	ACP	CCP	CIP	DIP	PVC
Pipe Size	0.064	0.008	0.112	0.006	0.006
<=4"	2	1	1.4	1.2	1.1
6"	1.1	1	1.2	1.2	1.1
8"	0.9	1	1	1.1	1
10"	0.8	1	0.9	1	0.9
12"	0.7	1	0.8	1	0.8
14"	0.6	1	0.7	0.9	0.8
16"	0.5	1	0.6	0.9	0.8
18"	0.5	1	0.5	0.8	0.8
20"	0.5	1	0.5	0.7	0.8
24"	0.5	1	0.5	0.6	0.8
27"	0.5	1	0.5	0.6	0.8
30"	0.5	1	0.5	0.6	0.8

Palo Alto Soils (Clay-like)

k_I Factors (Material + Diameter), cont'd

Base Rate	CU	HDPE	Steel	Unknown (same as CIP)
Pipe Size	0.02	0.01	0.15	0.112
≤4"	1	1	2	1.4
6"	1	1	1	1.2
8"	1	1	0.8	1
10"	1	1	0.7	0.9
12"	1	1	0.6	0.8
14"	1	1	0.6	0.7
16"	1	1	0.5	0.6
18"	1	1	0.5	0.5
20"	1	1	0.5	0.5
24"	1	1	0.5	0.5
27"	1	1	0.5	0.5
30"	1	1	0.5	0.5

Palo Alto Soils (Clay-like)

k2 Factors

Pipe Age, yr	ACP	CCP	CIP	DIP	PVC
Unknown	1	1	1	1	1
1-10	0.4	0.8	0.3	0.8	0.9
11-20	0.6	0.8	0.3	0.9	0.9
21-30	0.8	0.8	0.3	1	1.0
31-40	1	0.8	0.5	1	1.0
41-50	1.2	0.8	0.7	1.1	1.0
51-60	1.2	0.9	1	1.1	1.1
61-70	1.2	1	1.2	1.15	1.1
71-80	1.2	1.1	1.4	1.2	1.1
81-90	1.4	1.2	1.6	1.3	1.2
91-100	1.6	1.2	1.8	1.4	1.2
101-110	1.8	1.3	2	1.5	1.2
111-120	2	1.4	2	1.7	1.2
>120	2	1.5	2	2	1.2

Palo Alto Soils (Clay-like)

k2 Factors, cont'd

Pipe Age, yr	CU	HDPE	Steel	Unknown
Unknown	1	1	1	1
1-10	0.75	0.95	0.8	0.5
11-20	0.75	0.95	0.8	0.6
21-30	1	1	0.9	0.7
31-40	1	1	0.9	0.8
41-50	1.25	1.05	0.95	0.9
51-60	1.25	1.05	0.95	1
61-70	1.5	1.1	1	1.2
71-80	1.5	1.1	1.2	1.4
81-90	2	1.15	1.4	1.5
91-100	2	1.15	1.6	1.6
101-110	2.5	1.2	1.8	1.7
111-120	2.5	1.2	2.0	1.8
>120	2.5	1.2	2.5	2

Palo Alto Soils (Clay-like)

k₃ Factors

Rho	CIP, CU, Unknown	DIP	CCP	Steel	All non-metallic
1000	1.2	1.1	1.1	1.15	1.0
2000	1.1	1.0	1.0	1.1	1.0
3000	0.8	1.0	1.0	1.0	1.0
4000	0.7	1.0	1.0	1.0	1.0
5000	0.6	0.9	0.9	0.9	1.0
6000+	0.5	0.9	0.9	0.9	1.0

Rho adopted is at 5 feet bgs

Palo Alto Soils (Clay-like)

How to combine Pipe Aging with Earthquakes?

- Benefit Cost Ratio (BCR)
- $BCR > 1$, Replace the pipe
- $BCR < 1$, Let the customer be cheap

EXAMPLES


Parameter	<u>MainID</u> 7	<u>MainID</u> 4326	Units
<u>MainID</u>	7	4326	
Length	928.72	185.17	Feet
Year installed	1991	1971	
Age	20	40	Years
Material	CI	CI	
Diameter	6	4	Inches
Soil resistance	17402	28421	Ohm-cm
Liquefaction susceptibility	L	H	
Fault susceptibility	VL	VL	
Background repair rate	0.0243	0.1283	Repairs / mile / year
Number of Leaks	1	0	In past 24.5 years
Number of recent leaks	1	0	Since 1/1/2003
De-facto repair rate	0.1290	0.0045	Repairs / pipe / year
Outage time	6.79	6.05	Hours
Outage Length	750	500	Feet
Replacement Cost	\$83,585	\$11,110	
Repair cost per year	\$516	\$18	
Claim cost per year	\$52	\$2	
GDP loss per year	\$312	\$3	
Sales loss per year	\$1	\$0	
Repair costs per year (E)	\$882	\$23	Existing Pipe
Material Replacement Pipe	DI	HDPE	
Repair costs per year (N)	\$22	\$2	Replaced Pipe
NPV, Reduced repair costs	\$19,455	\$475	
BCR, Replacement (Repair)	0.233	0.043	
Losses per year, Seismic (E)	\$72	\$977	Existing Pipe
Losses per year, Seismic (N)	\$7	\$98	Replaced Pipe
NPV, Reduced seismic costs	\$1,465	\$19,893	
BCR, Replacement (Seismic)	0.018	1.791	
BCR, Total	0.250	1.833	

$r=4\%$, 60 Years


Example Results - Redwood City


Existing Pipe	Replaced Pipe	Seismic Hazards	Recent Breaks	Corrosivity	BCR Aging	BCR Seismic	BCR Total
6" CIP, 90 yrs	6" HDPE	PGV, PGD	1	High	0.46	2.14	2.6
6" CIP, 90 yrs	6" PVC	PGV	1	High	0.46	0.1	0.56
2" GIP, 90 yrs	6" PVC	PGV	1	High	1.05	0.13	1.18
12" DIP, 30 yrs	12" PVC	PGV	0	High	0	0.05	0.05
8" CIP, 50 yrs	8" PVC	PGV	3	Mod	1.29	0.08	1.37
20" CCP, 40 yrs	20" WSP	PGV, PGD	0	High	0.002	0.643	0.644

Aging Benefit-Cost Ratio Results



Seismic + Aging Benefit-Cost Ratio Results





Pipes Prioritized for Replacement

— BCR Model

— Older Model


Comparison of BCR Model (Left) to Older Model (Right)

Conclusions

- Beyond the initial "break in" period, there is no observable trend that says older pipes leak "much" more often
- Seismic only: upgrade only the worst pipes in zones with PGDs and very high economic activity
- Aging Only: replace if 2 or more breaks in past 8+ years; otherwise, live with repairs
- Seismic + Aging. Rank Replacement Priority using BCR Model

Age Based Model

- After the "break in" period, there is no empirical evidence to say that ferrous pipes leak at a higher rate as they age



- "If it ain't broke, don't fix it"

South Napa M 6.0 Earthquake of August 24, 2014

Prepared by:

Editor:

John Eidinger – G&E Engineering Systems

Investigation Team:

Alexis Kwasinski– University of Pittsburgh

Mark Yashinsky - Caltrans

John Andrew – California Department of Water Resources

Anshel Schiff – Precision Measurements

Alex K. Tang: L&T Consulting

Revision 1

March 17, 2015

Table of Contents

TABLE OF CONTENTS	I
1.0 INTRODUCTION	1
1.1 OUTLINE OF THIS REPORT	1
1.2 KEY FINDINGS	1
1.3 LIMITATIONS	4
1.4 ACKNOWLEDGEMENTS	4
1.5 TCLEE AND ASCE	4
1.6 ABBREVIATIONS	5
1.7 UNITS	5
1.8 LICENSE, COPYRIGHT AND CREATIVE COMMONS DEED	6
2.0 SEISMIC HAZARDS	7
2.1 LOCATION OF THE EARTHQUAKE	8
2.2 GEOLOGIC CONDITIONS AND LIQUEFACTION SUSCEPTIBILITY	15
2.3 SERA LISTINGS OF SHAKEMAP GROUND MOTIONS	20
2.4 SURFACE FAULTING	30
2.5 HOW ACCURATE ARE SHAKEMAPS	43
3.0 PERFORMANCE OF PG&E POWER SYSTEM	49
4.0 PERFORMANCE OF WATER AND SEWER SYSTEMS.....	56
4.1 CITY OF NAPA WATER SYSTEM	56
4.2 CITY OF VALLEJO SYSTEM	77
4.3 DWR - NBA	77
4.4 ST. HELENA.....	78
4.5 WATER SYSTEM NEAR EPICENTER	78
4.6 NAPA SANITATION DISTRICT	78
4.7 SONOMA VALLEY COMMUNITY SANITATION DISTRICT	87
5.0 PERFORMANCE OF HIGHWAY BRIDGES.....	88
5.1 NAPA RIVER BRIDGE ON ROUTE 37, 23-0064.	91
5.2 BRIDGE 21-0049	97
5.3 BRIDGE 21-0108 L/R	100
5.4 HIGHWAY 37	102
6.0 COMMUNICATIONS	103
6.1 AT&T	103
6.2 VERIZON	106
7.0 FIRE FOLLOWING EARTHQUAKE	109
8.0 GAS	112
8.1 PERFORMANCE OF 26 INCH PIPE AT FAULT CROSSING.....	112
8.2 OTHER ASPECTS OF THE GAS SYSTEM PERFORMANCE	114
9.0 OTHER	116
10.0 REFERENCES.....	117


September 15 2014. Shakemap, PGA (g), Max of NS, EW

SHAKEMAP EARTHQUAKE
ID= 72282711
Magnitude = 6.00
Factored by 1.00
PGA-g

0.70 +	Red
0.55 - 0.70	Blue
0.40 - 0.55	Green
0.25 - 0.40	Magenta
0.20 - 0.25	Grey
0.15 - 0.20	Cyan
0.10 - 0.15	Yellow
0.05 - 0.10	Light Grey


Scale. (Meters per Inch)

One Inch = 12444.
Meters/Pixel = 132.




Location of Water Pipe Breaks

NAPA ~ 125 Pipe Repairs
> 200 by Feb 2015



AMERICAN CANYON < 5 Pipe Repairs




VALLEJO ~ 54 Pipe Repairs



EBMUD ~ 2 Pipe Repairs a Day
is "business as usual"

SF ~ 2 Pipe Repairs



Elevation, Feet

0 - 100
100 - 200
200 - 300
300 - 400
400 - 500
500 - 600
600 - 4500



CITY OF NAPA
STREETS

Tank "B"



Tank "B"




Tank "B"



Tank "B" After Roof is Replaced



Tank "B"



Unanchored Steel Tank

Design by Pat Creegan, 1960 of Creegan and D'Angelo. C&D SF Office closed in 2015, RIP.

(Pat thought "R" is real... but it is not. See Paper on Magic R for steel tanks)

No Seismic Design Concepts


EBAA Flextend had been previously installed for Inlet-outlet pipe (good thing, BUT...)

The outlet pipe broke in the street, so the tank drained anyways (missed the big picture)

The Roof was damaged due to water sloshing and tank wall uplift (who cares, FEMA pays)

Napa replaced the roof


Then, Napa wanted to "raise" the roof top prevent future roof damage (IMHO, a waste of \$\$)



Sonoma County

Napa County

Soil Rho, Ohm-Cm, 5 foot depth







29

121

Pipe Damage +
Fault Offset Zone A



W. Imola

Pipe Damage +
Liquefaction Zone B

12


29

Water Pipe Repair Status



Observed Locations of Surface Faulting





29

121

12

W. Imola

29


Water Pipe Repair Type

- Cast Iron
- Asbestos Cement
- PVC C900
- Ductile Iron
- Steel
- Unknown

0 4 km

CAN SURFACE GEOLOGY EXPLAIN THE PIPE FAILURES?



-  af Artificial fill
-  Qhbm/af Estuarine deposits with areas of artificial fill
-  Qhbm Estuarine deposits
-  Qhay Latest Holocene alluvial deposits
-  Qhay/Qhb Latest Holocene flood plain and basin deposits
-  Qhs Holocene dune and beach sand
-  Qhb Holocene basin deposits
-  Qht Holocene terrace deposits
-  Qhf Holocene fan deposits
-  Qha Holocene alluvium, undifferentiated
-  Qs Late Pleistocene to Holocene dune sands
-  Qb Late Pleistocene to Holocene basin deposits
-  Qt Late Pleistocene to Holocene terrace deposits
-  Qf Late Pleistocene to Holocene fan deposits
-  Qa Late Pleistocene to Holocene alluvium, undifferentiated
-  Qpt Late Pleistocene terrace deposits
-  Qpf Late Pleistocene fan deposits
-  Qpa Late Pleistocene alluvium, undifferentiated
-  Qpmt Late Pleistocene marine terrace deposits
-  Qoa Early to middle Pleistocene alluvium
-  Qomt Early to middle Pleistocene marine terrace deposits
-  br Pre-Quaternary deposits and bedrock. Includes Quaternary landslides




CAN LIQUEFACTION EXPLAIN THE PIPE FAILURES?

- Pipes Already Repaired
- ▲ Pipes To Be Repaired

Liquefaction Susceptibility





Liquefaction Susceptibility

- Very high
- High
- Moderate
- Low
- Very low
- Not mapped
- Water


West Side Reservoir

W. Imola

Water Pipe Repair

- Pipe Repair

1,000 m



Liquefaction Susceptibility

- Very high
- High
- Moderate
- Low
- Very low
- Not mapped
- Water

Water Pipe Repair

- Pipe Repair

West Side Reservoir

W. Imola



West Side Reservoir




Liquefaction Susceptibility

-  Very high
-  High
-  Moderate
-  Low
-  Very low
-  Not mapped
-  Water

Water Pipe Repair

-  Pipe Repair

-  Liquefaction Effect Oservations (see text)



Location 1. Hilltop Drive

Residential Construction
1950s Vintage



Road Entirely Resurfaced After September 2014
Pipe Repair Post October 2014

Location 2. Mannering Street

Residential Construction
1950s Vintage




Road Entirely Resurfaced After September 2014
Pipe Repairs Post October 2014

Location 3. Mannering Street



Unreinforced concrete patio
Cracks due to differential settlements



Total Pipe Repairs, By Sept 15 2015 (add 50% Sept-Jan 2015)

Material	Repairs	% Repairs	% Pipe	Repair per Mile
AC	8	5%	10%	0.23
PVC	2	1%	2%	0.34
CI	123	75%	44%	0.82
DI	18	11%	34%	0.16
Steel	3	2%	9%	0.10
Other / unk	7	4%		
Total	163	100%		

Total Pipe Length, 337 Miles

Age (years)	PVC	DI	CI	AC	RCCP	STL	Total	Pct of Total
< 20	6,600	225,600				100	232,300	13%
20-40	24,300	370,500	83,400	14,100		100	492,400	28%
40-60		12,300	466,700	167,200	9,900	59,800	715,900	40%
60-80			173,100			100,400	273,500	15%
80-100			55,100				55,100	3%
> 100			10,300				10,300	1%
Total	30,900	608,400	788,500	181,300	9,900	160,400	1,779,500	100%
	2%	34%	44%	10%	1%	9%		

Length of Pipe in Napa Water System (2012, feet)

Breakdown of actual pipe damage in Napa Earthquake

Pipe Type	Length, System-wide (miles)	Repairs due to Shaking (PGV)	Repairs due to Liquefaction (PGD)	Repairs due to Surface Faulting (PGD)	Total Repairs, August 24 to Sept 15 2014
AC	34.34	2	0	5	7
CI	149.34	86	19	5	110
DI	115.23	8	4	5	17
PVC	5.85	2	0	0	2
STL	30.38	2	0	0	2
RCCP	1.88	0	0	0	0
UNK		22	0	3	25
Total	337.01	122	23	18	163

Breakdown of pipe damage in Napa Earthquake
due to Shaking (no liquefaction, no surface faulting)

Pipe Type	Length, System-wide (miles)	Actual Repairs due to Shaking	Forecast Repairs due to Shaking
AC	34.34	2	2.4
CI	149.34	86	88.5
DI	115.23	8	12.3
PVC	5.85	2	0.4
STL	30.38	2	5.0
RCCP	1.88	0	0.1
UNK		22	
Total	337.01	122	108.8


With 2015-vintage Seismic Models
including effects of Rho, corrosion

Breakdown of pipe damage in Napa Earthquake
due to Liquefaction

Pipe Type	Length, System-wide (miles)	Actual Repairs due to Liquefaction	Forecast Repairs due to Liquefaction
AC	34.34		
CI	149.34	19	21.2
DI	115.23	4	4.3
PVC	5.85		
STL	30.38		
RCCP	1.88		
UNK		0	
Total	337.01	23	25.5


With 2015-vintage Seismic Models
including effects of Rho, corrosion

PG&E Power Outages



PG&E Customers without Power

1.4% of PG&E's 5,100,000 Customers



Yellow: Napa

Orange: Rohnert Park

Green: Saint Helena


Cyan: Santa Rosa

Red: Sonoma Valley

Grey: American Canyon

Blue: Vallejo

Number of Power Outages (number of faulted feeders, or part thereof)



Yellow: Napa
 Orange: Rohnert Park
 Green: Saint Helena
 Cyan: Santa Rosa

Red: Sonoma Valley
 Grey: American Canyon
 Blue: Vallejo

PG&E Power Outages

- High Voltage Transmission. Most had been seismic upgraded between 2000 and 2012, many \$millions. **No material damage. No outages.**
- Low Voltage Distribution. Pretty good performance (**127 repairs, 37 hour restoration**). Why? Lessons learned in 1952 led PG&E to modify the way transformers are attached to wood poles: all through bolted, none on cross arms, none resting on platforms. Big repair crew (nothing else happening).

PG&E Distribution Damage


Repair Item	Total Manhours	Number of Repair Items	Average Manhours per Repair Item
Conductor	1147	68	17
Connector	42	4	11
Cross Arm	247	12	21
Cutout	41	3	14
Enclosure, Lid, Frame	24	1	24
Guy	45	6	8
Hardware / Framing	34	3	11
Insulator	42	3	14
Jumper	81.5	8	10
Switch / J-Box	21	1	21
Tie Wire	25	2	12
Transformer, Regulator Booster (OH)	630	8	79
Transformer Pad mount (UG)	28	2	14
Transformer Subsurface (UG)	71	2	36
Logistics	2000	4	500
Grand Total	4478.5	127	35




Primary

Secondary

Line Drop to customer




Swaying of pole and inadequate slack on secondary line drop to house led to failure of the insulator connection on the house.



Repair = "Western Union" Splice
Nearby cross arm was replaced.
Possible burn marks on conductors




Wire burn marks.
This failure mode can be prevented with “smart” de-energization at the substation.



cross arm damaged due to unbalanced "snap" loads



Overhead Distribution Repair Rate



Transmission Damage

Sorry! Really nothing major to report! PG&E did “a good enough” mitigation effort



Modern Control Building.... "many times stronger than code"

Old Control Building (Behind). Why replace it if it still plenty strong?
and Battery Enclosure (Front). Why build a Tesla when a Prius will do?



Everything OK at PGA = 0.30g.



Modern Transformer 230 kV - 60 kV (built 2010).

Anchorage capacity was sufficient so that $PGA = 0.30g$ was small enough to not overcome sliding / rocking.

Modern composite bushings.

Lots of cable slack.

No damage.



Modern Circuit Breaker 230 kV (built 2010).

Shake Table Tested to $PGA = 0.5g$.

Steel supports are elastic to $PGA \gg 1.0g$. (No "R" values allowed like for regular buildings)

Lots of cable slack.

No damage.



230 kV Horizontal Break switch atop heavily braced frame.

Lots of cable slack.

No damage.





230 kV. Wave trap supported by two post-insulators, on same stand with Trench CCVT (composite)

Prof. Anshel Schiff.

Prof Schiff is the “father” of seismic design of high voltage equipment.

Left: a modern circuit switcher (1999) (no damage).

Right: a “vintage” power transformer (with minor oil leaks).

A second transformer at this substation (not seen in this photo) is new and seismically qualified. So, even had the old transformer failed, customers would have had power within an hour



115 kV - 12 kV Bank 1

Oil leaks appears to be from top pipe connections (as expected / common)



Station Service Transformers. Heavy braced. No damage.



Vintage transformers. No damage at PGA $\sim 0.30g$. Well anchored.
A new parallel transformer bank was installed so these are somewhat "Redundant"




Upgrades of heavily loaded scaffolding might be a good thing.

Diagonal in scaffolding that was damaged in earthquake.

This is on “low voltage” side of yard.

If this rack had collapsed, (PGA = 0.6g?) there would have been long power outages to downtown Napa.


Now, re-assessing all such racks at key substations; some new racks already installed.



12 kV Circuit Breaker and switches
some settlement



12 kV Circuit Breaker and switches
some settlement





Unanchored Cabinets rocked to these positions (formerly cabinets were tight against each other). Mitigating this “housekeeping” weakness is an ongoing process.

Summary - Power

- Why did PG&E do so well? IEEE 693 and Bellcore and lessons learned from past earthquakes. Thanks to Anshel Schiff, Alex Tang (Nortel), Dennis Ostrom (SCE), Ed Matsuda (PG&E), Eric Fujisaki (PG&E), Leon Kempner (BPA), Lana Gilpin Jackson (BC Hydro), Ron Tognazini (LADWP), Craig Riker (SDG&E) and many others.
- These standards cost \$millions, and take decades to implement.

PG&E Gas Issues

- 160 loss of service due to damage to customer facilities
- PG&E responded to >8,000 service “tags” (report of gas odor, leak, safety check, ...)
- Total relights, appliance checks > 2,500 (926 in Napa, 110 in Vallejo)
- PG&E **replaced** 200 feet of 26-inch diameter Steel pipe that underwent some fault offset. No damage in old pipe. New pipe is ~2 times tougher.
- PG&E **replaced** 7,000 feet of 12-inch diameter PE pipe located in the fault zone (the pipe had no leak or apparent damage, but might be prone to pre-mature cracking)

64 m

Los-Cameros-Ave


26 inch Gas Pipe

Inferred location of buried power cables (not broken)

Utilities Building

1958 Building

Inferred location of buried water pipe (broken)







Line 021A.

**Surface
Cracking**



North

South



AT&T - Communications



Wall Panel Fell. Was held by 4 tabs, for future expansion. Building racking damaged the tabs. Panel fell onto HVAC equipment, damaging cooling system. PG&E power equipment was also damaged by the falling wall. Emergency generator failed to start. Back up batteries worked well. But, batteries need to be recharged.... a priority to get a generator to recharge the batteries. No real loss of service, as AT&T was able to respond.

Sewer

WWTP did well.
Why? found on
clay (no
liquefaction)

Sewer Pipes Broke
Repaired at fault
crossings

Residual pipe
damage remains to
be found



Zone with Concentrated Sewer Pipe Breaks




Figure 4-16. Location of Sewer Breaks

Type	Miles	Pct of Total
ABS Plastic	2	0.7%
AC	124	45.9
CI	1	0.4
Concrete	3	1.1
PVC	61	22.6
RCP	7	2.6
VCP	70	25.9
Other	2	0.7
Total	270	100%


Table 4-3. Length of Sewer Pipes – Napa (Miles)

Possible Rocking of Center Tower in Clarifier





Fire Following Earthquake




Fire Ignitions Attributed to the August 24 2014 Main Shock

No.	Time of Report (approx.)	Location	Description (see below)
1	0330	Orchard Ave	Napa Valley Mobile Home Park (NVMHP) – actually two ignitions – see narrative
2	0400	Laurel St. (no street number)	2 story, 2 unit residence, roof collapse, started fire
3	0500	162 Robin at Solano	Dbl wide home
4	0630	1990 Trower	Smoke inside structure
5	0730	770 Lincoln x Soscol	Electrical fire in substructure of a mobile home
6	1200	4072 Rohlffs Way x Fair	Kitchen fire in single story multi-unit senior housing complex

FFE

- There were several fire ignitions
- There was NO wind at the time of the earthquake
- If it had been windy (say 20 mph), with the loss of water pressure due to damage in the water system, then a LOT of Napa would have burned to the ground



Summary - Underground Pipes

- Damage to buried water (and sewer) pipes is the ELEPHANT in the room.
- PG&E's buried pipes are MUCH more "resilient" than Napa's buried water pipes
- If we do not install seismic-resistant pipes in a pro-active manner, some pipes are doomed in future earthquakes... Long outages.... Economic Consequences.... Loss of Water for Fire Fighting.... Raw sewage dumped into our waterways....
- ALA 2005 is a Guideline to design buried water pipes. It might be time to make it a mandatory Standard.
- At \$2 million per mile, this is not going to be cheap, and this is not going to happen overnight. Use BCR Models to help decide. Use real data, not "make believe". If we do not start, we will never finish.

Do Utilities Do or Not Do?

- Do-ers: Knowledge of weaknesses, followed by careful assessment, followed by capital improvements.
- Non-Do-ers: Unaware of the risks. Or, aware of the risks, but unwillingness to fund.