

Magna M 5.7 2020

John Eiding, G&E

eidinger@geEngineeringSystems.com

www.geEngineeringSystems.com

October 23 2020

Copyright, G&E Engineering Systems Inc., 2020

Acknowledgements: Pete McDonough, PG&E, Dominion Energy, Enstar provided information about the performance of gas systems in the Magna and various other earthquakes in California and Alaska. Mobile home information provided by Bruce Maison.

Agenda

- Magna M 5.7, March 18 2020
- Gas Pipes in Ridgecrest 2019, Alaska 2018, Napa 2014, Eureka 2010, Northridge 1994, Imperial Valley 1979, San Fernando 1971, Long Beach 1933, and others
- Data analysis (fragility)
- The issue of mobile homes and gas meters

Magna
Natural Gas System

Magna M 5.7

- M 5.7 4 km NNW of Magna
- Depth 11.9 km
- Wednesday March 18 2020 7:09:31 am local time

Natural Gas Operations



- Questar was the operator for many years
- Dominion Energy bought Questar in Utah
- The Transmission System was spun off Dominion Energy
- Dominion includes: local sub-transmission, distribution for Salt Lake City, Park City and other areas

Gas Leaks, March 18 2020

- Very minor damage (items falling, etc.)
- No structural damage (moment frame building designed in 1990s) designed to remain operational during a worst case EQ
- 48% of customers who turned off their gas at the meter actually had leaks. This compares with 1994 Northridge (10%) and 1987 Whittier Narrows (22%)

Gas

- Significant trailer park damage (about 49 trailers at MMI VII). There were no fires at the trailer parks (unlike Northridge)
- No main leaks. Dominion uses MDPE extensively for distribution pipes
- 9 earthquake valves activated within MMI VI and VII zones. These appear to have been activated above the ANSI standards of PGA = 0.16g. These are valves in service lateral lines.
- 391 leaks. 97% were on meter sets. 3% were on underground service laterals: 4 tap-to-main leaks; 1 corroded steel service
- 113 leaks on customer piping: 21% were water heater related (compared to 75% for Whittier). Most new water heaters are installed with seismic straps, which is something that Dominion has stressed.



Earthquakes in 2020

impacts to gas
impacts to power




Mobile Home Park light damage



Mobile Home Park heavy damage

M 5.7 March 18 2020 Epicenter




Electric Transmission Lines

- 500 kV
- 345 kV
- 230 kV
- 138 kV
- 46-66 kV

PGA, g

- 0.02
- 0.04
- 0.08
- 0.12
- 0.16
- 0.2
- 0.24
- 0.28
- 0.32
- 0.36
- 0.38



Transmission Lines

- 500 kV
- 345 kV
- 230 kV
- 138 kV
- 46-66 kV


▲ High Voltage Substations

□ Overhead Towers

PGA, g

- 0.02
- 0.04
- 0.08
- 0.12
- 0.16
- 0.2
- 0.24
- 0.28
- 0.32
- 0.36
- 0.38

0 10 20 km




Transmission Lines

- 500 kV
- 345 kV
- 230 kV
- 138 kV
- 46-66 kV

▲ High Voltage Substations

PGA, g

- 0.02
- 0.04
- 0.08
- 0.12
- 0.16
- 0.2
- 0.24
- 0.28
- 0.32
- 0.36
- 0.38




Transmission Lines



- 500 kV
- 345 kV
- 230 kV
- 138 kV
- 46-66 kV

▲ Substation

PGV, cm/sec

- 1
- 2
- 4
- 6
- 8
- 10
- 12
- 14
- 16
- 18
- 20
- 22
- 24
- 26
- 28
- 30
- 32
- 33







LIQUEFACTION-POTENTIAL MAP FOR A PART OF SALT LAKE COUNTY, UTAH

UTAH GEOLOGICAL SURVEY

Public Information Series 25

August 1994


Salt Lake
Marina
area



This map is for general reference only and was modified from Anderson, L.R., Keaton, J.R., Spitzley, J.E., and Allen, A.C., 1994, Liquefaction potential map for Salt Lake County, Utah, Utah Geological Survey Contract Report 84-4, 48 p., scale 1:48,000. Copies of this report are available at the Utah Geological Survey.

Utah Geological Survey³

California, Anchorage





◆ Earthquakes that damaged Gas pipes (year)

Reference: Seismic Fragility of Natural Gas Transmission Pipelines and Wells, by G&E Engineering Systems Inc, Report R130.01.01, 259 pages, Revision 3, July 15 2020. Available at: www.geEngineeringSystems.com

2010

2014

1906

1957

2007

1952

1994

1971

1987

1933

1979


SoCalGas and PG&E have a lot of pre-1930 gas-welded steel pipes


1971 San Fernando > 50 steel gas transmission pipe repairs

1994 Northridge > 30 steel gas transmission pipe repairs


Why has SoCal Gas had 80+ steel T pipe failures?

Why has PG&E had 0 steel T pipe failures?





- Pipes subject to offset in 1979
- 2010 gas T pipes



Post 1979 pipe.
Note alignment to place pipe in net tension in future events

Not replaced

1979 Imperial Valley - > 2 steel gas transmission pipe replacements

USA
Mexico

Anchorage M 7.0
Nov 30 2018

**ANCHORAGE, ALASKA,
M_w 7.1 EARTHQUAKE OF
NOVEMBER 30, 2018
LIFELINE PERFORMANCE**

By

JOHN M EIDINGER and JOHN DAI

**The Council of Lifeline Earthquake Engineering
*TCLEE No. 5***

Revision A, June 27 2019

**THE COUNCIL
OF LIFELINE
EARTHQUAKE
ENGINEERING**





Epicenter of M 7.1 Earthquake



Beluga

Pt MacKenzie

Anchorage

Turnagain Arm

Hope

Eagle River

Wasilla

Farm Loop

Palmer

Butte

Eklutna

Knik-Fairview

Big Lake

Meadow Lakes

Houston

Willow

Susitna River

Nancy Lake State Recreation Area

Fishhook

Sutton Alpine

Chickaloon

Matanuska River

Chugach State Park

Alyeska

Portage

Esther Island




ENSTAR

- Natural Gas Company for Anchorage and area (1961)
- 440 miles of transmission pipes
- 3,200 miles of distribution pipes (1,000 Cu laterals, 100 replacements per year)
- 15 repairs in Nov 30 2018 earthquake (to date) 12 corrosion 3 EQ
- 2,000 customer calls for re-light: Enstar asked public NOT to turn off valves unless they smelled gas
- \$1 million in repair cost
- A longer duration event would have been MUCH worse (PGDs)


AEC ShakeMap : 7 miles NW of Elmendorf AFB


Nov 30, 2018 08:29:29 AM AKST M 7.1 N61.35 W149.96 Depth: 46.7km ID:20419010





PERCEIVED SHAKING	Not felt	Weak	Light	Moderate	Strong	Very strong	Severe	Violent	Extreme
POTENTIAL DAMAGE	none	none	none	Very light	Light	Moderate	Mod./Heavy	Heavy	Very Heavy
PEAK ACC.(%g)	<0.05	0.3	2.8	6.2	12	22	40	75	>139
PEAK VEL.(cm/s)	<0.02	0.1	1.4	4.7	9.6	20	41	86	>178
INSTRUMENTAL INTENSITY	I	II-III	IV	V	VI	VII	VIII	IX	X+

Scale based upon Worden et al. (2012)











- Chugach Electric Association (CEA)
- Matanuska Electric Association (MEA)
- Seward Electrical System (SES)
- Golden Valley Electric Association (GVEA)
- Anchorage Municipal Light & Power (ML&P)





MAJOR DAMAGE

7.06 km

Ami Storage

Image Landsat Copernicus

Google Earth

Imagery Date: 12/30/2016 lat: 61.229575° lon: -149.748460° elev: 67 m eye alt: 30.39 km

Chugach Electric Association
Point MacKenzie Substation
Photo Pre-EQ, July 2018
230 138 kV
Lat 61.2496
Long -150.0268

230 kV Yard
17/22 switches collapse
Rigid bus with plungers
\$2 M to \$8 million to re-build
1+ Year re-build



Image © 2019 DigitalGlobe

94 m

9996

Imagery Date: 7/30/2018 lat 61.249570° lon -150.026851° elev 31 m

Google

Diam. 4-inch t = 0.25 inch steel gas pipe
No leaks
Very soft soils (Su ~ 300 psf?)
Will be Replaced
Still in service June 2019
Alignment: Based om Enstar survey.
Yellow and green lines approximate

Pre-Earthquake

Post-Earthquake

16 feet

350 feet





~4.5" x 0.25" steel gas pipe
 No leaks
 Very soft soils ($S_u \sim 300$ psf?)
 Will be Replaced
 Still in service EQ+6 months

Pre-Earthquake

Post-Earthquake

16 feet



Photo Dec 1 2018



Photo Dec 1 2018

Vine road in wasilla

Photo June 20 2019

California - Ridgecrest 2019

SERA Forecast Leaks and Repairs

Ridgecrest M 7.1

Category	Entire System Inventory length (km)	M 7.1 Repairs	Pct of All Repairs	Actual
Transmission	10,703	2	3%	2
Distribution	69,551	12	16%	11
Service Laterals	41,266	59	81%	~ 300 1 week ~ 540 1 year
Total		73	100%	

General Approach

- Examine Historic Gas Leaks After Earthquakes
 - Ridgecrest 2019, Napa 2014, Alum Rock 2007, Eureka 2010, Loma Prieta 1989.
- Develop Fragility Models based on this data

Discussion

- What is a Leak?
 - 10± parts per Million? (Background rate)
 - 10± parts per Billion
 - Smell Test? (Serious)
 - Ignition: > 50,000 parts per Million
- Different Utilities do this differently!

Inyo County

Kern County


San Bernardino County

Trona

Argus

South Trona

2019 Ridgecrest




All Leaks


Full Scale 10 km



- Transmission Steel Pipe
- Distribution Steel Pipe
- Distribution Plastic Pipe



Ridgecrest



Trona

M 7.1 Earthquake

PGV, cm/sec



Calibration Earthquake 2019 Ridgecrest

PGV (cm/sec)	Mains	Service Laterals	Regulators
0-1			
1-2			
2-4			
4-6		1	
6-8			
8-10			
10-12		1	
12-14		9	
14-16		11	
16-18	6	13	
18-20	3	12	
20-22	2	11	
22-24		4	1
24-26		21	
26-28	1	11	
28-30	1	32	
30-32	1	32	
32-34	2	60	
34-36	9	73	
36-38	5	25	
38-40	1	8	
Total	31	324	


Initial Survey, July 2019

Note

PGV
Based on ShakeMap

There are some serious
Issues with the ShakeMap
Motions for Trona area

Some adjustment for PGDs



Leak Cause	Ridgecrest	Systemwide
Undetermined	15.0%	24.3%
Atmospheric Corrosion	0.2%	1.9%
Construction Defect	5.1%	4.7%
Compression Coupling	0.2%	0.1%
Damage by Earth Movement	0.4%	0.2%
Digin/Excavation	0.9%	2.7%
Damage by Third Party (non-digin)	0.4%	0.1%
Earthquake	0.5%	0.0%
External Corrosion	0.7%	0.4%
Fire or Explosion on Customer Facility	0.2%	0.0%
Leak - Unknown	33.8%	45.3%
Material Failure	8.8%	1.3%
No/Deteriorated Pipe Dope	31.6%	15.9%
Other	0.5%	0.9%
Other Natural Forces	0.2%	0.3%
Previously Damaged	0.4%	0.1%
Plastic Embrittlement	0.7%	0.3%
Unknown (Replaced Facility)	0.4%	0.4%
Weld Failure	0.2%	0.2%


Notable differences. Why?

Material failures: earthquake adds stress to buried pipe: leading to higher material failure rate (Most to riser insert kits or plastic tee caps. Pipe age might also have something to do with this (Trona pipes are old)



Shaking of house impacts service riser / aggravates pipe dope at threaded connections (Leaks through threads not generally hazardous)

Transmission Pipes


SoCalGas Transmission Pipes



SoCalGas Transmission Pipes




SoCalGas Transmission Pipes




PG&E Transmission Pipes

Earthquake	M	Year	Repair History Quality	No. Transmission Repairs Reported L = Likely P = Possible	No. Transmission Pipes Replaced for Stress Relief
San Francisco	7.9	1906	Marginal	Many	N.A.
Kern County	7.3	1952	Very good	1 L	2
Daly City	5.7	1957	Poor	Some	0?
Greenville	5.8	1980	Poor	None ?	?
Coalinga	6.3	1983	Poor	Some	?
Morgan Hill	6.2	1984	Marginal	1 P	0
Ridgemark	5.4	1986	Marginal	0	0
Calaveras	5.6	1986	Marginal	0	0
Fort Tejon	5.2	1988	Marginal	0	0
Loma Prieta	6.9	1989	Marginal	0	0
Cape Mendocino	7.2	1992	Poor	Some ?	0
Salinas	5.1	1998	Marginal	1 P	0
Yountville	5.0	2000	Marginal	0	0
San Simeon	6.5	2003	Good	0	0
Alum Rock	5.6	2007	Marginal	1 L 2 P	0
Eureka	6.5	2010	Good	1 L	0
Napa	6.0	2014	Good	2 P	2
Ridgecrest	7.1	2019	Very good	0	2
Total				3 L, 6P	6


PG&E Transmission Pipes



PG&E / SoCalGas
Steel Transmission Pipes
(excluding pre-1930 SoCal pipes)



SoCalGas: repairs to
pipe barrels




PG&E: all repairs to
appurtenances

Distribution Pipes

Earthquake	M	Year	Repair History Quality	No. Distribution Repairs Reported
San Francisco	7.9	1906	Marginal	Many
Kern County	7.3	1952	Very good	Unknown
Daly City	5.7	1957	Poor	Some
Greenville	5.8	1980	Poor	None reported
Coalinga	6.3	1983	Poor	Some
Morgan Hill	6.2	1984	Marginal	None reported
Ridgemark	5.4	1986	Marginal	None reported
Calaveras	5.6	1986	Marginal	?
Fort Tejon	5.2	1988	Marginal	No data
Loma Prieta	6.9	1989	Marginal	270
Cape Mendocino	7.2	1992	Poor	Some likely
Salinas	5.1	1998	Marginal	None
Yountville	5.0	2000	Marginal	A few?
San Simeon	6.5	2003	Good	0
Alum Rock	5.6	2007	Good	0
Eureka	6.5	2010	Very good	279
Napa	6.0	2014	Very good	388
Ridgecrest	7.1	2019	Very good	356
Total				1,293


270 count excludes an additional ~300 Leaks in San Francisco

Includes: Mains Only. Red Line = Backbone Curve



Includes: Loma Prieta 1989, Eureka 2010, Napa 2014, Ridgecrest 2019


Includes: Laterals + Risers Only. Green Line = Backbone Curve



Includes: Loma Prieta 1989, Eureka 2010, Napa 2014, Ridgecrest 2019

Ridgecrest






Ridgecrest M 7.1 Earthquake

SHAKEMAP EARTHQUAKE
ID= 38457511
Magnitude = 7.10
Factored by 1.00
Maximum = 125.88
PGV-cm/sec

113.29 +
89.00 +
64.70 +
40.41 +
32.35 +
24.29 +
16.24 +
8.06 +



6" Transmission Pipe

10" Transmission Pipe

30" Transmision Pipes

SHAKE MAP EARTHQUAKE

ID= 38457511



Magnitude = 7.10

Factored by 1.00

Maximum = 125.88

PGV-cm/sec



- 113.29 +
- 89.00 +
- 64.70 +
- 40.41 +
- 32.35 +
- 24.29 +
- 16.24 +
- 8.06 +



6"

10"

10"



M 7.1

M 6.4

Trona

Ridgecrest


Little Lake Fault Zone

Garlock Fault



Epicenters, July 4 1030 am - July 9 540 pm Pacific Daylight Time
28 Earthquakes M 4.5 - M 7.1

35.371°N; 117.360°W






115 kV Downs - Searles

PG&E 10-inch Gas Transmission Pipe

115 kV Inyokern - Searles

35.6488, -117.455926


-  Simplified Location of M 7.1 event fault offset
-  PG&E Gas Transmission Pipe
-  SCE 115 kV Overhead Line

3095 ft

©2018 Google

1995

Imagery Date: 7/1/2017 lat 35.648800° lon -117.455926°



Searles 12-inch Water Pipe

SCE 115 kV Downs - Searles

SCE 33 kV

PG&E 10-inch Gas Transmission Pipe

SCE 115 kV

Up

- ◆ 115 kV Wood Pole
- ◇ 115 kV Double (or Triple) Wood Pole
- 33 kV Wood Pole

- Simplified Location of fault offset
- PG&E Gas Transmission Pipe
- SCE 115 kV Overhead Line
- Water Pipe



Looking Southeast



Original pipe partially excavated



PG&E 6-inch Gas Transmission Pipe


- Simplified Location of M 6.4 fault offset
- PG&E 6-inch Transmission Gas Pipe

575 ft

575 feet

Aerial Photo Taken July 13 2019

Google Earth



6" Pipe Left Lateral Offset




Original pipe partially excavated

Original pipe after fully excavated



Trona Gas Regulator Station Damage Assessment

Extensive cracking and settlement zone at Trona Regulator Station (east view; map) and concentric “headscarp” crack (south view; photo)





Trona Gas Regulator Station Damage Assessment



Settlement and lateral movements in station pad fills removed support for piping/valves. Settlement & lateral displacement is up to 0.5-1 foot.



Apparent settlement/lateral spread headscarp at northwest corner of station. Searles Lake is off the photo to the left (east), and crack patterns and direction of extension suggest lateral movements toward the lake.

General cracking is pervasive throughout station pad fill.




Differential settlement and lateral displacement across the station pad and foundations

Risers and Meters

Is this "ideal" if the house slides off its foundation?




Community Close to Epicenter



Mobile Homes (MH) (aka manufactured homes)

- One community severely affected
- 48 of 206 MHs dislodged = 23%
 - Many fell to ground
 - No fire ignitions from gas leaks
- First EQ with significant damage to MHs having **tie-down anchors**
 - CA damage mostly in **unanchored** MHs

Tie-Down Lateral Bracing



Support Systems



Chassis Girder

Tie-Down

Steel Pier

**Temp Wood
Cribbing**

Community Close to Epicenter

Western Estates


Some damaged gas lines in this neighborhood

Dominion Energy shut off gas supply to the entire neighborhood

Wednesday March 18 2020 7 am. Earthquake occurs

Thursday: Dominion Energy had crews in the area making repairs

Friday: gas restored to non-damaged houses




Ref. Bruce Maison, California

Vance Strunk (Strunk Construction, Salt Lake City)


Update June 2020

Short Duration & Strong Shaking



LKC acceleration in N-S direction

LKC exceeds Design Earthquake (IBC Code)



LKC versus Building Code Spectrum

Double-Wide Home



Single-Wide Home



Underneath Home


Chassis Girder

Broken Strap

Girder Slipped Off Piers



Underneath Home



Chassis Girder

Towing Hitch

Steel Piers Tipped

Components Nearby Crushed



Corrosion Problem

Strap connection to
concrete foundation



Broken Tie-Down Straps



Takeaways

- Tie-downs for wind forces **NOT** sufficient for EQ
 - Tension straps overloaded in EQ
- Corrosion played role in damage
 - But some collapses even with pristine tie-downs
- Detailed report in-progress
 - Available on EERI ***Learning from Earthquakes*** clearinghouse later this year

Gas Meter Sets

- Every mobile home had a gas meter set.
- Each meter set is supported by the riser and a supplementary post or pipe tube; meters are not supported by mobile homes.
- All meters had flex hose from the low pressure gas outlet to the mobile home. Commonly 1 foot± of slack in the flex hose.
- Some mobile homes impacted the meter / riser. Many meter sets were tilted. Skirts of mobile homes were damaged where impacted. Various leaks through threaded fittings.
- Some meter sets that did not have impacts with mobile homes were tilted after the earthquake.